

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions
- TPSGC
11 Laurier St./11 rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Construction Services Division/Division des services de
construction
11 Laurier St./11 Rue Laurier
3C2, Place du Portage
Phase III
Gatineau, Québec K1A 0S5

Title - Sujet S.J.C. Building Deconstruction	
Solicitation No. - N° de l'invitation EP076-131647/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client R.010592.002	Date 2012-12-19
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-345-61469	
File No. - N° de dossier fg345.EP076-131647	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-01-10	Time Zone Fuseau horaire Eastern Standard Time EST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Nealon, Shawn	Buyer Id - Id de l'acheteur fg345
Telephone No. - N° de téléphone (819) 956-3391 ()	FAX No. - N° de FAX (819) 956-8335
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Sir John Carling Building, Central Experimental Farm, 930 Carling Avenue, Ottawa, Ontario.	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EP076-131647/A

Client Ref. No. - N° de réf. du client

R.010592.002

Amd. No. - N° de la modif.

007

File No. - N° du dossier

fg345EP076-131647

Buyer ID - Id de l'acheteur

fg345

CCC No./N° CCC - FMS No/ N° VME

THE PURPOSE OF THIS AMENDMENT IS TO ISSUE ADDENDUM # 4.

End of Amendment.

Solicitation No. - N° de l'invitation

EP076-131647/A

Client Ref. No. - N° de réf. du client

R.010592.002

Amd. No. - N° de la modif.

007

File No. - N° du dossier

fg345EP076-131647

Buyer ID - Id de l'acheteur

fg345

CCC No./N° CCC - FMS No/ N° VME

Addendum No. 4

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

1 SPECIFICATIONS

- .1 Section 01 11 00 - Summary of Work
 - .1 Change Sentence 1.1.1.3.3 to read as follows: "Remove service tunnel. There is no asbestos within the service tunnel."
 - .2 Add Article 1.1.1.10 to read as follows: "Remove electrical transformers. They are dry type transformers and do not contain PCBs."
 - .3 Add Subsection 1.3.4 to read as follows: "PWGSC is undertaking Project R.045209, AAFC - West Annex Redevelopment. The drawings and specifications for this project are attached and issued for information."
- .2 Section 01 14 25 – Designated Substances Report
 - .1 Add Subsection 1.1.14 with heading "ASBESTOS: Presumed", and with paragraphs to read as follows:

"Removal of mechanical duct systems and air handling units, with no fireproofing overspray on systems, follow Type 2 (Intermediate) asbestos abatement work procedures in accordance with Section 02 82 00.02.

Visually similar fireproofing in room spaces adjoining those with asbestos containing fireproofing (50-75% Chrysotile Asbestos) are to be treated as Presumed Asbestos Containing Materials (PACMs) with the same asbestos type and content. Removal of fireproofing to follow Type 3 (Maximum) asbestos abatement procedures in accordance with Section 02 82 00.03.

Spray material applied within floor slab spaces, reference Section 01 14 25 Table 1 samples Z6913-017 and Z6913-018, as such to be handled as a Friable Amosite containing (ranging from 50 to >75%) with removal following Type 3 (Maximum) asbestos abatement work procedures in accordance with Section 02 82 00.03, with appropriate respiratory protection.

Fireproofing material presumed to be present in exterior soffits of the Tower, were not sampled, and as such are to be handled as a Friable PACM, Amphibole Form with removal following Type 3 (Maximum) asbestos abatement work procedures in accordance with Section 02 82 00.03, with appropriate respiratory protection.

Fireproofing to be presumed on deck and structural building features at an average depth of 30 mm. Soffit spaces to be included in scope of work and any asbestos containing fireproofing materials to be removed before demolition.

Spray material applied within floor slab spaces, not sampled, as such to be handled as a Friable PACM as an Amphibole Form with removal following Type 3 (Maximum) asbestos abatement work procedures in accordance with Section 02 82 00.03, with appropriate respiratory protection.

All layers of mastic applied to steel or Styrofoam to be presumed asbestos containing (5 to 10% Chrysotile). Steel can be cleaned and removed as scrap.

Fire cut off, located in Tower at inside face of round air ducts in exterior wall, and extending from slab to slab of each floor, presumed to be 25 mm thick and asbestos containing. Handle as a Friable PACM, Amphibole Form with removal following Type 3 (Maximum) asbestos abatement work procedures in accordance with Section 02 82 00.03, with appropriate respiratory protection.
- .3 Section 02 41 21 - Deconstruction of Structures
 - .1 Add Subsection 1.10.3 to read as follows: "Live Loads"
 - .2 Add Article 1.10.3.1 and Sentences to read as follows: "The original structural construction drawings indicate the following live load design capacities as follows:
 - .1 Tower - basement, 1st floor and 11th floor: 150 pounds per square foot
 - .2 Tower - 2nd to 10th floors: 100 pounds per square foot
 - .3 Tower - roofs: 60 pounds per square foot
 - .4 East Link and East Annex - 1st floor: 125 pounds per square foot
 - .5 East Link and East Annex - 2nd floor: 105 pounds per square foot

.6 East Link and East Annex - roofs: 60 pounds per square foot"

2 ADDENDA

.1 Addendum 2

.1 Remove Item 1.2. in its entirety.

END OF ADDENDUM