

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 3C9

Title - Sujet 1100 CLASS FUELING CABINETS	
Solicitation No. - N° de l'invitation F5561-122424/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F5561-12-2424	Date 2012-12-11
GETS Reference No. - N° de référence de SEAG PW-\$HAL-302-8833	
File No. - N° de dossier HAL-2-69280 (302)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-01-03	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Gaudreau, Michel	Buyer Id - Id de l'acheteur hal302
Telephone No. - N° de téléphone (902) 496-5245 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation amendment No 001 is issued for the purpose of providing answers to questions submitted to the contracting authority.

1. On drawing number 12062-380-S-001 item 13 and subsequent drawings do the stainless steel doors require painting the same as the cabinet or can they be left in a natural finish?

Doors are not painted. They are just stainless.

2. Drawing number 12062-380-S-001 item 7 : Is the shelf, expanded mesh Stainless Steel?

No, the current cabinet shelf mesh is painted steel.

3. Drawing number 12062-380-S-001 item 25: is the 1in 44 Ball Valve Stainless Steel?

If possible, yes

4. What is the specification for the gasket material for the vents and openings or are they painted finish to painted finish?

Gaskets shall be ANSI B16-21 C.A.F. with P.T.F.E Envelopes.

5. Drawing number 12062-380-S-002 : Does the Flammable liquid signage have to bi-lingual.?

No

6. Drawing number 12062-380-S-001 item 27: The drawing indicates Jet A however the legend says Jet A1 Earth Point advise please what is required.

See attached picture for clarification.

It should be Jet- A-1 as indicated on the sign and also have a placard as shown for flammable liquid.

Both of these items are stickers as indicated.



JET A-1