

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jaspe**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**  
**Bid Fax: (780) 497-3510**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jasper**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**

<b>Title - Sujet</b> Bowden/Drumheller GI-GO	
<b>Solicitation No. - N° de l'invitation</b> EW038-123225/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> CSC	<b>Date</b> 2012-05-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-308-9349	
<b>File No. - N° de dossier</b> PWU-1-34835 (308)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-05-31</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Dong (RPC), Michael	<b>Buyer Id - Id de l'acheteur</b> pwu308
<b>Telephone No. - N° de téléphone</b> (780) 497-3874 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**THIS AMENDMENT NUMBER SIX (6) IS RAISED TO PROVIDE THE FOLLOWING:**
**Bowden/Drumheller GI GO Questions and Answers #2 - 16 May 2012**

- Q1. The floor plans for the GI and GO buildings show steel columns spaced at 7500 c/c and 6100 c/c. Is it a requirement that the steel columns stay at these dimensions? If so, all perimeter columns will not be concealed within the exterior wall system and the structural steel design becomes more difficult. Or is it up to the design-builder to determine where the steel columns are placed?
- A1. The steel columns do not have to stay with the same format spacing. Load could be transferred to walls. Final Structural design is up to the design builder. Room dimensions remain same as per floor plans.
- Q2. Room data sheet, "meeting room large". Indicates domestic hot and cold water service required but does not indicate type of fixture, nor are they indicated on the drawings?
- A2. Stub in drain and hot-cold water supply lines to wall between the Mechanical Room and Meeting Room Large. No fixtures required.
- Q3. Please specify a minimum window area for open workstations (for GI or GO) - window area is not in the room data sheet.
- A3. As per room data sheets, it indicates to refer to floor plan drawing for window locations. On the drawings there are a number of windows indicated in each area. Each window is to be min 1.44m<sup>2</sup>.
- Q4. GO - Meeting Room Large - There is no minimum area given for the exterior windows. Please confirm minimum window area.
- A4. Total of 5.76m<sup>2</sup> (4 x 1.44m<sup>2</sup>).
- Q5. GO - Staff Locker Room, Washroom 1 and Washroom 2 - There is one mirror c/w shelf indicated in the accessories list. The terms of reference do not specify a mirror /shelf combo, only a mirror. Can you please confirm what the minimum requirement is?
- A5. Delete need for shelf. Follow spec section description.
- Q6. Are Standard accessories required only. Grabbers? Other stainless steel accessories?
- A6. See Turnkey Project Manual Section 4.2.23 (page 66). Fixtures that are not BF can match qualities listed. Determining the Grab bar requirements and other elements of accessibility would be considered to be part of the design process to meet Barrier Free/Accessible design Standards.
- Q7. What is the depth of the 1200mm x 1200mm manholes for the concrete encased duct bank system?
- A7. The interior dimensions are to be 1200mm x 1200mm x 1200mm. See attached sheet with nominal dimensions and details for the telecommunications and electrical manholes.

Solicitation No. - N° de l'invitation

EW038-123225/A

Amd. No. - N° de la modif.

006

Buyer ID - Id de l'acheteur

pwu308

Client Ref. No. - N° de réf. du client

CSC

File No. - N° du dossier

PWU-1-34835

CCC No./N° CCC - FMS No/ N° VME

---

**This Revision also includes attachments.**

Drawings, Specifications, and addendum are now available for viewing and downloading in a Portable Document Format (PDF) or in a standard paper version. Tenderers should note that Attachment 1 (ATT 001), Attachment 2 (ATT 002), Attachment 3 (ATT 003), Attachment 4 (ATT 004), and Attachment 5 (ATT 005) contain the Drawings, Specifications, and addendum Package (DSP) which consists of PDF files organized in an industry recognized directory structure.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**