

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet 50 Bed Living Unit, Westmorland Ins	
Solicitation No. - N° de l'invitation EC016-130878/A	Amendment No. - N° modif. 014
Client Reference No. - N° de référence du client R.043929.001	Date 2012-09-13
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3101	
File No. - N° de dossier PWB-2-35024 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-19	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro 14 est soumise et comprend la modification numéro 14 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Modification numéro 14

QUESTIONS ET RÉPONSES

Q1: Area noted in Item #4 on sheet A-001.1 appears to be smaller than we calculate floor areas to be based on floor plan measurements listed on A-100, 101 & 102.

R1: Sheet A-001.1 is a Code Review sheet, and does not give areas suitable for pricing. Bidders should rely on their own calculations using figured dimensions.

Q2: Drwg A-404 Wall Type P5 t location near Grid F/G-18 is inconsistent (in width) with P5 size at GridK-17.

R2: Allow for all wall types tagged on plans as described on sheet A-001.0, Notes & Legends. Plans may not show exact thickness of partitions.

Q3: Near Grid G-17 on A-404 there is Wall Type 5.1, but this type is not listed in the Wall Type Legend on A-001.

R3: Wall Type tag should read 'P5'.

Q4: Should there be a 600mm grab bar with the 900mm in the barrier free washrooms?

R4: Additional grab bar not required by code for this type of WC.

Q5: Should there be a soap dish for showers in room 115 & 215 North, South & East wings? Detail 5/A-503 does not show any and there is no side elevation.

R5: Soap dishes are integral with the shower unit.

Q6: Re Section 1 on A-306: the alum drip is drawn as it comes almost to the outer edge of the gutter, is this the intention?

R6: Drawing error - flashing should extend only 25mm over edge of gutter.

Q7: The Roof Legend on A-001 for R2 Roof type calls for 305mm **acoustic** insulation, is this a typo?

R7: Description is correct. Roof insulation as specified is 'Acoustic', although in this application it has both thermal and acoustic properties.

Q8: Security Plates for wiring devices - are they required for this type of building?

R8: Wiring devices in Inmate Rooms to be fitted with security screws. Outside these rooms, standard plates / fastenings required.

Q9: E504: INTERCOM RISER: The conduit indicated is 1/2" spec. calls for minimum 3/4" please review.

R9: 3/4" should be used as per spec.

Q10: E-504: Intercom Riser: What is required in Building F58 between the Sub-Elect.Room and existing Aiphone Master Station?

R10: Intercom cable to be routed along existing cable trays within building F58.

Q11: E-301: Room-113: Interval Timer Do you have a Model number in mind?

R11: This is called for as part of the Mechanical Specification to control the 'Smudging' ventilation in this room. Refer to detail 6/MC-402. No specific manufacturer is called for.

Q12: Would you please clarify the following:

Section 09 65 19 Resilient Flooring Page 2

PART 2 - PRODUCTS

2.1 VINYL COMPOSITE TILE

.1 Resilient vinyl tile: to **ASTM F1700**, Class III, Type B..etc. **What you are describing is Luxury Vinyl, but confusing when the 2.1 says Vinyl Composite Tile.**

ASTM F1700 refers to LVT (Luxury Vinyl Tile)

Vinyl Composite Tile is ASTM F1066, Class 2.etc.

The flooring subcontractors are wondering what they should price being either VCT or LVT.

R12: Vinyl Composite Tile is intended

Q13: Wood framing note #3 on S-501 calls for roof sheathing (plywood or OSB) to be 12.7mm. Details 8, 9, 10, and 11 on S-406 call for 16mm sheathing, R2 on A-001 calls for 15.9mm T&G plywood. Please clarify thickness and type of material.

R13: Roof type description on A-001 is correct. Roof sheathing is 15.9mm t&g plywood.

Q14: What size and color of tile that is required for this project?

R14: Specification Section 09 30 13, Part 2.1.1 Covers wall tile. This is a very generic spec., as all that will be required is a plain 150mm square tile, white or another colour from the manufacturer's standard range.