

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jaspe**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**  
**Bid Fax: (780) 497-3510**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jasper**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**

<b>Title - Sujet</b> Bowden/Drumheller GI-GO	
<b>Solicitation No. - N° de l'invitation</b> EW038-123225/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> CSC	<b>Date</b> 2012-05-11
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-308-9349	
<b>File No. - N° de dossier</b> PWU-1-34835 (308)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-05-31</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Dong (RPC), Michael	<b>Buyer Id - Id de l'acheteur</b> pwu308
<b>Telephone No. - N° de téléphone</b> (780) 497-3874 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**This amendment is raised to address the following suggestions/questions**

- Q1. How many reviews are required by the HRSDC Fire Protection Engineer (FPE)?
- A1 The FPE is to review hard copy sets of the 50% and 99% design submissions. Design Builder may continue design work during the review period but must incorporate all FPE comments in the next design submission. Additional submissions can be made to determine the Fire Protection requirements, prior to the 50% submission being prepared. Revise Article 2.6.1.2 of Project Manual from "three (3)" to "four (4)" paper copy sets.
- Q2. What is the requirement for the goose neck , spray wand and floor drain in the "Electrical, Telecom and LAN Room" Room Data Sheet?
- A2. Delete these requirements from the Plumbing Section of the Room Data Sheet.
- Q3. Should the flooring in the Staff Shower Room be slip resistant to match the staff locker room?
- A3. Yes. Amend the Room Data Sheet for the Staff Shower Room to include the special requirement for slip resistant flooring.
- Q4. What are the sizes of the whiteboards indicated on the Room Data Sheets?
- A4. Large Whiteboards are to be 1.2m x 3.05m in the Meeting Room Large, Multipurpose Room (1), Multipurpose Room (2), Program Room (1) and Program Room (2). Revise Room Data Sheet of Multipurpose Room (1) to include "Large White boards x 3" in Specialties section. Revise Specialties section of Program Room (2) Room Data Sheet to indicate "Large white boards x 2. Only 1 required in the two smaller rooms." Whiteboard in Meeting Room Small to be 1.2m x 2.4m. Revise Room Data Sheet to include "Small white board x 1" in Specialties section.
- Q5. What is the second door style to the Staff Locker Room.
- A5. Door style E.

- Q6. Are 2 Garbage cans required for the Staff locker room?
- A6. Garbage cans, soap dispensers and paper towel dispensers are not in contract. Delete requirement for garbage cans in the staff locker room. Delete requirement for garbage cans, soap dispensers and paper towel dispensers from washrooms and staff shower room.
- Q7. What is the door style for the Primary Door to the Warehouse?
- A7. Door style D.
- Q8. The second door style on the Main Vestibule, Stair Room Data Sheet is indicated as both A and H. Is H an error?
- A8. Delete door style H.
- Q9. For the Open workstations, the primary door section indicates HM/paint and secondary door indicates Door style E. Are these correct?
- A9. Doors are not required. Delete these requirements.
- Q10. Is A/C required in the warehouse?
- A10. No. Change Air Conditioning requirement under Warehouse Room Data Sheet from "Other" to "Not Required".
- Q11. Are the distances of the cable and conduit runs indicated on the "Utility Connection Detail Summary" measured from the termination point in the LAN, Electrical or other designated rooms?
- A11. The Cable and conduit distances indicated on the "Utility Connection Detail Summaries" are measured from the face of the GI or GO building, where the new concrete encased conduit duct bank begins. Any additional length of cable and interior or exterior concrete encased conduit that is required to connect from the GI or GO building termination point to the new concrete encased conduit duct bank, is to be included in the Design Builder's tender price.

**All other terms and conditions remain the same**