

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
 Bid Receiving Public Works and Government
 Services Canada/Réception des soumissions/Travaux
 publics et Services gouvernementaux Canada
 The Cambridge Building
 3 Queen Street/3, rue Queen
 Charlottetown
 Prince Edward Island
 C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Darlene Reay, either by facsimile or by e-mail at:
 darlene.reay@pwgsc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
 The Cambridge Building
 3 Queen Street/3 rue, Queen
 PO Box 1268/CP 1268
 Charlottetown
 Prince Ed
 C1A 4A2

| | |
|--|---|
| Title - Sujet Structure 406 Repairs, Launching | |
| Solicitation No. - N° de l'invitation E0226-122949/A | Amendment No. - N° modif. 001 |
| Client Reference No. - N° de référence du client R.050638.001 | Date 2012-03-09 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWC-008-3062 | |
| File No. - N° de dossier PWC-1-34206 (008) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-16 | Time Zone Fuseau horaire Atlantic Standard Time AST |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Reay, D (PWC) | Buyer Id - Id de l'acheteur pwc008 |
| Telephone No. - N° de téléphone (902) 566-7518 () | FAX No. - N° de FAX (902) 566-7514 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|---|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

This Addendum is raised to provide the following answers to questions provided by bidders.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

ANSWERS TO QUESTIONS

1. **QUESTION**

Why is the new deck to be double spiked ?

ANSWER

It was a design decision to double spike the new decking.

2. **QUESTION**

Why is the front bottom wale being removed, the elevation of the deck is not changing and you are only lowering the bottom wale 75mm?

ANSWER

The top wale must be lowered to accommodate the new pile cap. The bottom wale must also be lowered so that there will not be a requirement to drill new holes in the fenders or wale.

3. **QUESTION**

Provide the model or size of the mooring cleat.

ANSWER

Details of the mass/size/shape and material type for the mooring cleat is provided on Detail 3/M2 of the contract drawings and in paragraph 2.4 in Section 05 50 00 - Metal Fabrications of the contract specification.