

The following changes to the tender documents are effective immediately and will form part of the contract documents:

SPECIFICATIONS:

Questions and Answers:

Question: Reference Section 01 11 00 Page 3 at Item 1.1.4.6 reads: "...Only clean material will be put in the excavation after the geotextile liner is installed." What are the dimensions of the excavation / geotextile liner?

Answer: The estimated size of the liner required would be for a 20 m by 20 m excavation (400 square meters of liner required). It is very difficult to say what the exact depth of the tank is, since we do not have previous as-builts or any other information. However, based on previous experiences, please assume the bottom of the tank is 4 m below surface.

- END -