

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Saint John Steel Sheet Pile Repair	
Solicitation No. - N° de l'invitation E0227-130927/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.051108.001	Date 2012-07-26
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-3099	
File No. - N° de dossier PWB-2-35033 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-08-02	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. One (1) is being issued to include the following questions and answers.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 1.

QUESTIONS AND ANSWERS

Q1. On drawing 4 of 4 in section "B" it is noting to use existing angle and bolts to support new continuous timber member. All other details are noting to use new materials.

A1. The angle and bolts are to be new.

Q2. Section 01 29 00 – On page 2 it is noting "Division 1" Site Office is to be measured for payment as a lump sum but there is no bid item for this on the tender form unit price table?

A.2 There will be no Departmental Representative's Site office. Ignore references In Section 01 55 00 part 3 and section 01 29 00 part 2.

Q3. Section 03 20 00 – Concrete Reinforcing. Is this section applicable as we are using fibre reinforced concrete?

A3. The section is not applicable.

Q4. Section 31 11 00 – Sitework, Demolition and Removals. Items 1.1.2.6 and 3.6.2. What methods are we allowed to use (grinding, water blast, etc) and can this material be dropped into the water. If it has to be collected what methods are we to use?

A4 As the work is in the water column use of chemical cleaners would be prohibited. The material is marine growth and does not need to be collected.

Q5. CEAA Report – Item 4.0, 3rd paragraph is noting the installation of cathodic protection. Is this part of our scope of work and if so can you please provide details?

A5 The cathodic protection refers to future work which is not included in this project.

Q6. if they form and pour both sides of the wall at once, is it still necessary to install the 3mm plate over the holes?

A6. The reason we have the sections poured separately is because it is very difficult to do the tremie pour from both sides of the wall as you will have to raise the tremie pipe at the same rate on both sides to ensure you displace the water evenly. We have had experiences on other projects where water gets trapped and creates voids in the wall.

Q7. In areas where there is sound steel can mechanical fasteners be used instead of welding the support angles?

A7. The angles must be adequately secured. Other alternatives could be considered during the shop drawing submission process.