

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> Reshingle Roofs, Nova Institution	
<b>Solicitation No. - N° de l'invitation</b> EC016-122834/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> R.043945.001	<b>Date</b> 2012-03-07
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-3050	
<b>File No. - N° de dossier</b> PWB-1-34200 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-13</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Cette modification de l'invitation numéro six (6) est soumise et comprend la modification numéro 6 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

### **QUESTIONS ET RÉPONSES**

Q1: Can a Waste Container for the old shingles be placed on site and removed when full? Say once every week or every two weeks. Or do we have to remove it daily with a dump truck or trailer ?

R1: Waste containers has to be removed daily.

Q2: Staging:- Can it be left up till roof completed? Does it need to be horded off at bottom say up 8 ft with plywood to keep people off?

R2: The staging can be left till the roof is completed as long as its horded off at bottom with plywood (height of plywood 8 ft min) to keep inmates off staging.

Q3: Washrooms: Is there on being provided for workers by owners ? or do we supply Portable Toilet. If so can it be left near work zone if locked to pole and door locked when workers not on site?

R3: Portable toilet is allowed on site as long its locked at all times.

Q4: Can all material for the complete project be delivered at once and stored beside each unit if tarped?

R4: Material cannot be stored within fence area. A space outside the fence/compound will be determine once the contractor is on site.

Q5: Who supplies and pays for commissionaire? Owner or General Contractor

R5: Nova Institution.

---

Q6: Eaves trough - How many downspouts per each unit?

R6: 2 for large roofs, 1 for small roof.

Q7: Step Flashing – Can existing step flashing be reused or does the siding have to be removed and new step flashing added?

R7: Re-use existing flashing.

Q8: Can we leave construction staging in place during reroofing and are there restrictions such as closing of the base when not in use?

R8: Waste containers has to be removed daily.

Q9: Can we leave a locked construction trailer on site during construction?

R9: No it cannot be left within the fence/compound, Construction trailer can be left outside of compound - to be determine once contractor is on site.

Q10: Are washroom facilities provided and if not can we place a portable toilet on site during construction?

R10: Portable toilet is allowed on site as long its locked at all times

Q11: Can we place an open dumpster on site during construction?

R11: Waste containers has to be removed daily

Q12: I request clarification of sections 1.2 and 1.3 (warranty) contained within document "Division 07 - Thermal and Moisture Protection". Are these sections suggesting that the manufacturer guarantee to cover labour to replace defective shingles and if so what is the period?

R12: Article 1.2, we are simply extending the warranty period from 12 to 24 months. The contractor is responsible for that aspect of the warranty. Article 1.3, means that if there is a defect with the material within the said period, the manufacturer shall be responsible for material and

---

about cost. The manufacturer will have to submit a certificate outlining the conditions of the warranty for their product.

Q13: Are the buildings to be resingled one-storey or two-storey?

R13: Building R1, R2, R3 & R4 are two storeys and the PFV is one storey.