

ADDENDUM No.01, dated 2013-01-04.

This Addendum shall form part of documents referred to in "Articles of Agreement" as "Plans and Specifications".

The Plans and Specifications are amended as follows:

SPECIFICATIONS

FIRE STOPPING

Section 07 84 00

2012-12-14

3.4 SEQUENCING OF OPERATION

1. Paragraph 3.4.3.1: Delete in its entirety and replace with the following:

“.1 Remove insulation from area of insulated pipe and duct where such pipes or ducts penetrate fire separation unless ULC certified assembly permits such insulation to remain within assembly.”

FINISH HARDWARE

Section 08 71 11

2012-12-14

2.1 MATERIALS

1. Paragraph 2.1.3.3: Delete in its entirety and replace with the following:

“.3 Provide request to exit switches with doors with magnetic locks.”

2. Delete paragraph 2.1.4.1.2 in its entirety.

3. Paragraph 2.1.10: Delete in its entirety and replace with the following:

“.10 Magnetic Lock - Grade 1, 2.2 kN (500 lbs) holding force, magnetic bond sensor, door position switch, relock time delay. Power

supply and necessary request exit switches as per code."

2.2 MISCELLANEOUS
HARDWARE

1. Delete Article 2.2 in its entirety.

3.2 INSTALLATION

1. Delete paragraph 3.2.3 in its entirety.

HARDWARE SCHEDULE

1. Delete existing document and replace with attached document "Hardware Schedule" consisting of 4 pages.

FIRE EXTINGUISHERS AND	Sect 10 44 16.19
SAFETY BLANKETS	
	2013-01-04

Add the attached new Section 10 44 16.19 - Fire Extinguishers and Safety Blankets, dated 2013-01-04 and consisting of 2 pages.

DRAWINGS

ARCHITECTURAL:

DWG.A-001 ABBREVIATIONS, LEGENDS AND NBC MATRIX

1. Replace existing Dwg.A-001 with attached Dwg.A-001 dated 2013-01-04.

DWG.A-210 FIRING RANGE PLANS

1. Replace existing Dwg.A-210 with attached Dwg.A-210 dated 2013-01-04.

DWG.A-220 TRAINING BUILDING FOUNDATION, FLOOR, ROOF AND REFLECTED CEILING PLANS

1. Replace existing Dwg.A-220 with attached Dwg.A-220 dated 2013-01-04.

DWG.A-510 FIRING RANGE SECTION AND WALL SECTION

PWGSC Ontario	FENBROOK INSTITUTION	Addendum No.01
Region Project	FENBROOK FIRING RANGE	Page 3
Number R.052544.001	AND TRAINING BUILDING	2013-01-04

1. Replace existing Dwg.A-510 with attached Dwg.A-510 dated 2013-01-04.

DWG.A-511 FIRING RANGE SECTION & DETAILS

1. Replace existing Dwg.A-511 with attached Dwg.A-511 dated 2013-01-04.

ELECTRICAL:

DWG.E-210 FIRING RANGE ELECTRICAL LIGHTING LAYOUT

1. Replace existing Dwg.E-210 with attached Dwg.E-210 dated 2013-01-04.

The four (4) electromagnetic locks and associated emergency pull stations at the exterior doors are deleted from detail 3 - Lighting Layout and from detail 4 - Safety/Notification Wiring Schematic. The corresponding note #05 is revised. Four (4) wall mounted type D1 light fixtures are added at exterior doors.

DWG.E-220 TRAINING BUILDING ELECTRICAL LIGHTING, POWER & SYSTEMS LAYOUT

1. Replace existing Dwg.E-220 with attached Dwg.E-220 dated 2013-01-04.

The panel schedules are updated to show the connected loads and the number of poles.

End of Addendum No.01, dated 2013-01-04, consisting of 4 pages and the following attached documents:

Specifications:

New Section 10 44 16.19 - Fire Extinguishers and Safety Blankets, dated 2013-01-04 (2 pages)

Revised document "Hardware Schedule" (4 pages)

Drawings:

Dwg.A-001 - Abbreviations, Legends and NBC Matrix, dated 2013-01-04

Dwg.A-210 - Firing Range Plans, dated 2013-01-04

PWGSC Ontario	FENBROOK INSTITUTION	Addendum No.01
Region Project	FENBROOK FIRING RANGE	Page 4
Number R.052544.001	AND TRAINING BUILDING	2013-01-04

Dwg.A-220 - Training Building Foundation, Floor, Roof and Reflected Ceiling Plan, dated 2012-01-04

Dwg.A-510 - Firing Range Section and Wall Section, dated 2013-01-04

Dwg.A-511 - Firing Range Section & Details, dated 2013-01-04

Dwg.E-210 - Firing Range Electrical Lighting Layout, dated 2013-01-04

Dwg.E-220 - Training Building Electrical Lighting, Power & Systems Layout, dated 2013-01-04