

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Const.Svc,14 Bed Live Unit,Nova Ins	
Solicitation No. - N° de l'invitation EC016-133509/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.043957.001	Date 2013-04-22
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3237	
File No. - N° de dossier PWB-2-35164 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-04-30	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. Four (4) is raised to include the following Addendum No. Four (4).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 4.

1. ENQUIRIES DURING THE SOLICITATION PERIOD

Please note that no further enquiries will be accepted.

2. SPECIFICATIONS

1. Reference Specification Section 12 21 16:

.1 Please ensure you are reading the correct documents.

3.1 Install blinds surface mounted to underside of lintel at window head at exterior walls of Office, Program Room, Interview Room & Meeting Room windows only, in accordance with manufacturer's instructions .

. 2 Reference Specification Section 31 20 00:

.1 The geotechnical report was issued in a previous addendum.

. 3 Reference Specification Section 07 52 00:

.1 Reference Clause 2.2.4, 'Acceptable Materials', add the following:

".3 Manufacturer: Temple Island Gypsum, Model: Green Glass Roof Board."

.4 Reference Specification Section 28 16 00:

.1 Reference Clause 1.1.4, 'General', add the following:

".2 Electrical Contractor is to engage the services of Marcomm or Senstar to make the final connections for Security Systems equipment to the existing Institution Security Systems. Provide all necessary programming as required."

.5 Reference Specification Section 28 23 00:

.1 Reference Clause 1.3, 'General Requirements', add the following:

"4 Electrical Contractor is to engage the services of Marcomm or Senstar to make the final connections for video surveil/ance equipment to the existing Institution Security Systems. Provide all necessary programming as required."

.6 Reference specifications section 28 23 00

.1 Delete the supply and installation of CCTV equipment. Conduit pathways to be provided as indicated on contract drawings.

.7 Reference specifications section 28 16 00 - 2.4

.1 Revise security equipment cabinet manufacturer to R.F. MOTE, #RFM-COLO-219 (24" width x 36" depth) clw field reversible doors, 4" cooling fan kit and all originally specified internally mounted equipment.

.8 Reference specifications section 27 10 05 - 2.9

.1 Revise structured wiring equipment cabinet manufacturer to R.F. MOTE, #RFM-COLO-219 (24" width x 36" depth) clw field reversible doors, 4" cooling fan kit and all originally specified internally mounted equipment.

.9 Reference specifications section 09 65 19

.1 Delete Clause 3.2.1 ".1 Fully grind new concrete floors."

.10 Reference Specification Section 07 46 13:

.1 Delete Subsection 2.1 - Metal Cladding and Components

3. DRAWINGS**.1 Reference Section Detai11/A305:**

.1 Add note: Continuous 18ga bent metal connection to beam with power actuated fasteners @ 200 D.C. max .

. 2 Add Note: Wood blocking with 6mm Dia bolts @ 600mm o.c .

.2 Reference Floor and Wall Finish Schedule A004:

.1 Add: Elevator floor finish - VT1

.3 Reference Exterior Elevations A201 :

.1 The metal roof pitch is 5/12.

.4 Reference Section Details A305:

.1 Detail 2/305, Aluminium Vented Soffit as noted .

. 2 Detail 3/305, Soffit to be constructed of Aluminium panels with z-girt support, 2" rigid insulation, air/vapour barrier, exterior sheathing, steel stud framing, infill cavity with batt insulation .

.5 Reference Enlarged Floor Plans Level 1 Area "An A401:

.1 Wire mesh to be installed behind gypsum board on all walls in Lan Room 115. Full height of wall.

.6 Reference Millwork and Washroom Elevations A603:

.1 Remove "100mm COVE BASE" from washroom elevations. Wall tile to extend down to floor.

.7 Reference Site Grading Plan C103:

.1 The vertical posts for the handrail should be spaced at 2.4 m MAX and also located at changes in direction. Similar to the stair handrail, top of top bar to be 812 mm above ramp, bottom of bottom bar to be 355 mm above ramp.

.8 Reference drawing E505

.1 Reference to 'OM3" fiber cable on detail 4 to be revised to 'OM1' indoor/outdoor rated fiber cable

.2 Detail 3 to be revised to indicate a 6 strand OM-1 fiber cable to run between security electronics cabinet and data cabinet.

.9 Reference drawing E506

.1 Delete #2 bonding conductor from underground service entrance fed from pole mounted transformers.

Solicitation No. - N° de l'invitation

EC016-133509/A

Client Ref. No. - N° de réf. du client

R.043957.001

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWB-2-35164

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

.10 Reference Section Details A305:

.1 Correction: Revise Detail 3/305, Soffit finish to be metal soffit as per Specification Section 07 46 13- 2.2.