

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British Columbia
V6Z 2V8
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 2V8

Title - Sujet Aeration Tower Modification	
Solicitation No. - N° de l'invitation F1700-120200/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1700-120200	Date 2012-07-18
GETS Reference No. - N° de référence de SEAG PW-\$PWY-004-6729	
File No. - N° de dossier PWY-2-35074 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-07-25	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mestry, Ruth (PWY)	Buyer Id - Id de l'acheteur pwy004
Telephone No. - N° de téléphone (604) 775-9385 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Quinsam River Hatchery, Campbell River, B.C.	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

18 July, 2012

Addendum No. 1

The following changes/clarifications in the tender documents are effective immediately.
This addendum will form part of the contract documents.

IMPORTANT NOTICE TO BIDDERS

MANDATORY REQUIREMENT:

Code of Conduct Certifications - Consent to a Criminal Record Verification

Pursuant to section GI01 of the General Instructions to Bidders R2710T, the bidders must submit with their bid by bid solicitation closing date:

- a. a complete list of names of all individuals who are currently directors of the Bidder and
- b. a properly completed and signed consent form, for each individual named in the aforementioned list. The form PWGSC_TPSGC 229 is available on line at WEB site <http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/documents/229.pdf>

APPENDIX 1 - COMPLETE LIST OF EACH INDIVIDUAL WHO IS CURRENTLY ON THE BIDDER'S BOARD OF DIRECTORS

***NOTE TO BIDDERS
WRITE DIRECTOR'S SURNAMES AND GIVEN NAMES IN BLOCK LETTERS***

APPENDIX 2 - CONSENT TO A CRIMINAL RECORD VERIFICATION FORM (PWGSC-TPSGC 229) PROPERLY COMPLETED AND SIGNED, FOR EACH INDIVIDUAL NAMED IN THE AFORMENTIONED LIST. (ATTACHED AS A PDF FILE)

Addendum No. 1

The following changes in the tender documents are effective immediately. This addendum will form part of the Contract Documents.

1. The section 10 73 00 it asks for protective cover to have a full time on staff licensed engineer and for the manufacturers to be approved a minimum of ten days before the bid. This spec for a 15' x 8' shelter. Can the person doing the structural steel build and install it as long as they provide engineered drawings?

The building manufacture does not need to be approved before bid. Yes, the person doing the structural steel can build and install the shelter as long as they provide engineered drawings for approval before construction of the shelter.

2. Can the 12" supply header have grooved tees rather than welded tees so we can fabricate it on site making it cheaper?

We assume you are talking about the 12" supply header underneath the new aeration column. Grooved tees are acceptable alternatives to welded tees, but the piping will have to be supported from the structural framing above. A piping support plan will have to be supplied the Departmental Representative for approval prior to installation of the supply header.

3. Can the piping that goes to and from the turbine be grooved?

The piping going to and from the turbine shall be flanged. This is to facilitate ease of assembly/disassembly of the system for inspection and maintenance.

4. Much of the piping has too many fittings to coat the inside of the pipe. Can it be changed to stainless to eliminate the coating or can additional flanges be added to achieve the inside coating?

The piping running to the turbine can be either 304 stainless steel or epoxy coated mild steel.

5. How long is the aeration tower able to be shut down for to complete this work? In the past there is a really long lead time on receiving the equipment. Sixteen weeks seems really tight. Is there any room to extended the construction time?

This is an operating facility and the aeration tower will be in operation during construction and cannot be shutdown. It is the contractor's responsibility to isolate their work in the aeration tower without effecting operations or allowing contaminants to enter the rearing water supply.

Solicitation No. - N° de l'invitation

F1700-120200/A

Client Ref. No. - N° de réf. du client

F1700-120200

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWY-2-35074

Buyer ID - Id de l'acheteur

pw004

CCC No./N° CCC - FMS No/ N° VME

The construction time will be extended to twenty-four (24) weeks. However, all work over the aeration reservoir must be completed in the original 16 week time frame.

6. It states multiple time in the specs that the Bidder will not be allowed to change the project team members or subcontractors after award of contract without specific prior approval by the Departmental Representative. Is the Contractor going to have to list their team after the tender close and prior to award?

The successful bidder shall supply a list of subcontractors after contract award, but prior to the start of construction.

End of Addendum No. 1

Solicitation No. - N° de l'invitation

F1700-120200/A

Client Ref. No. - N° de réf. du client

F1700-120200

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWY-2-35074

Buyer ID - Id de l'acheteur

pw004

CCC No./N° CCC - FMS No/ N° VME

BID AND ACCEPTANCE FORM (BA)

BA01 IDENTIFICATION

Aeration Tower Modification - DFO
Quinsam River hatchery, Campbell River, B.C.

BA02 BUSINESS NAME AND ADDRESS OF BIDDER

Name: _____

Address: _____

Telephone: _____ Fax: _____ PBN: _____

BA03 THE OFFER

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the Total Bid Amount of

\$ _____ excluding GST/HST.
(amount in numbers)

BA04 BID VALIDITY PERIOD

The bid shall not be withdrawn for a period of 30 days following the date of solicitation closing.

BA05 ACCEPTANCE AND CONTRACT

Upon acceptance of the Contractor's offer by Canada, a binding Contract shall be formed between Canada and the Contractor. The documents forming the Contract shall be the contract documents identified in Contract Documents (CD).

BA06 CONSTRUCTION TIME

The Contractor shall perform and complete the Work within twenty-four (24) weeks from the date of notification of acceptance of the offer.

BA07 BID SECURITY

The Bidder is enclosing bid security with its bid in accordance with GI09 - Bid Security Requirements of R2710T - General Instructions to Bidders.

BA08 SIGNATURE

Name and title of person authorized to sign on behalf of Bidder (Type or print)

Signature

Date

**FOR GOVERNMENT USE ONLY
POUR USAGE DU GOUVERNEMENT SEULEMENT**

A

**PRIVACY ACT STATEMENT
ÉNONCÉ CONCERNANT LA LOI SUR LA PROTECTION DES RENSEIGNEMENTS PERSONNELS**

B

**BIOGRAPHICAL INFORMATION - Must be completed by the individual
RENSEIGNEMENTS BIOGRAPHIQUES - À remplir par l'individu**

C

**CONSENT - Must be signed by the individual
CONSETEMENT - Doit être signé par l'individu**

D

**ADMINISTRATIVE INFORMATION - Internal Government Use Only
RENSEIGNEMENTS ADMINISTRATIFS - Pour usage interne du gouvernement seulement**