

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, 12th floor
800,rue Burrard, 12e étage
Vancouver
British Columbia
V6Z 2V8
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 2V8

Title - Sujet Construction Work - GI/GO	
Solicitation No. - N° de l'invitation EZ899-123251/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2012-04-24
GETS Reference No. - N° de référence de SEAG PW-\$PWY-005-6661	
File No. - N° de dossier PWY-1-34511 (005)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-06-01	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Pillay, Sal (PWY)	Buyer Id - Id de l'acheteur pwy005
Telephone No. - N° de téléphone (604) 775-9386 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Mission Institution and Kent Institution, Mission and Agassiz	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Answers to questions received by Contractors/Consultants

Q1. Room Data Sheets call for air conditioning in the following rooms, which are typically not air conditioned. Please confirm that cooling is required in these rooms"

- A. Staff Locker Room
- B. Warehouse - Air conditioning is marked as "Other" - is cooling required ?
- C. Staff Shower room
- D. Janitor's Closet
- E. Storage and Support

A1. The entire building shall have air conditioning as specified; therefore those rooms shall be air conditioning.

Q2. Occupancy listed in room data sheets for various meeting rooms and open workstations varies widely. For example, there will be 2 occupants regularly at the open workstations, but a maximum of 20, and regular occupancy of 12 in the multi-purpose room, but a maximum of 50. Is the cooling to be designed for the expected regular occupancy or for the maximum. If sized for the maximum, the cooling will be greatly oversized for the regular occupancy occupancy, which will result in short cycling of equipment, and thermal comfort issues.

A2. The mechanical design shall meet the requirements and space comforts for maximum occupancy of each room. The mechanical system shall provide the flexibility of control and operation to meet the variable occupancy loads (from low to maximum) and thermal loads.

Q3. Appendix D specification, 8.2 Heating and Cooling Plants, page 107 says that the "proposed" heating source is gas fired condensing boilers. Is this a requirement, or just a preference?

A3. Appendix D specifications, 8.2 Heating and Cooling Plants, the proposed heating source is gas-fired condensing boilers. This is a requirement for the Mission and Kent Sites.