

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Bowden Demarcation Fence	
Solicitation No. - N° de l'invitation EW038-131625/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EW038-131625	Date 2012-10-18
GETS Reference No. - N° de référence de SEAG PW-\$PWU-909-9560	
File No. - N° de dossier PWU-2-35244 (909)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-10-25	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mayhew (RPC), Sylvia	Buyer Id - Id de l'acheteur pwu909
Telephone No. - N° de téléphone (780) 497-3645 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

ADDENDUM NUMBER TWO (2)

1. General

- 1.1 This Addendum is issued prior to Tender closing to identify the revisions as noted herein.
- 1.2 All such revisions will become part of the Work and the effects shall be included in the Tender Price.
- 1.3 All work shall be performed in accordance with the Contract Documents.

2. Drawings

- 2.1 Drawing B-C11: Note 2 has two components identified as 'Outer Perimeter Fence' and 'Inner Perimeter Fence'. Refer to the appropriate component when referencing the drawing.
- 2.2 Drawing B-C13: The reference to Note 2 shown on located at the top of the page refers to both the inner and outer perimeter fence.
- 2.3 Drawing B-C13: The reference to Note 2 located below the Inner Perimeter Fence that reads "Note 2 (begins 23m from the fence corner, ends at 142m) refers only to the Inner Perimeter Fence, and is referenced to the Inner Perimeter Fence component of Note 2 on Drawing B-C11.
- 2.4 Drawing EB-1: Notes and Scopes notes are to be interpreted to mean that all motors, components, conductors, etc. are to be replaced.
- 2.5 Drawing EB-1: Note 3 reads "Contractor to utilize existing gate control panel to control the gates. Contractor to duplicate existing control configuration. Existing Conduit and conductors used for controls shall be cut, capped and abandoned."
This is to be interpreted to mean that the conduit and conductors are to be replaced with new, and will match the existing. The existing Control Panel is to remain in place and is intended to be reused with the new motor and new components, with the new wiring to replicate the existing. The intent is that the existing motor control panel for the gates retain the present gate operation format.

End of Addendum No. 2