

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> Const.Svcs, Westmorland Inst, N.B.	
<b>Solicitation No. - N° de l'invitation</b> EC016-132714/A	<b>Amendment No. - N° modif.</b> 018
<b>Client Reference No. - N° de référence du client</b> R.043939.001	<b>Date</b> 2013-02-06
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-3192	
<b>File No. - N° de dossier</b> PWB-2-35125 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2013-02-12</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Tender Amendment No. Eighteen (18) is raised to include the following Addendum No. Eighteen (18).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

Addendum No. 18.

ITEM	REFERENCE	DESCRIPTION
1.	Drawing E300, Light Fixture H	.1 Light fixture H is specified as a shower light in each of rooms 115 and 116 and is indicated as an 'H' in a circle symbol.  .2 There are also eleven (11) type H light fixtures (an 'H' in a square symbol) that are located along grid line B in room 100-1 to 100-10. These light fixtures are mounted on the steel columns 2500mm A.F.F. and are a STONCO Cat. #TLW042HFL1W 42 watt compact fluorescent or equivalent from Cooper, Lithonia and Hubbell.
2.	Drawing E100, E500, .1 Addendum #9, Spec Section 26 12 13	The three (3) pole mounted transformers are to be 167KVA each and are to be installed to NB Power Standard Construction Practices detail ED19-167.
3.	Drawing E500, .1 Spec Section 26 24 02	<b>Question:</b> I would like to clarify that in the main switchboard 'P', that you do require fusible disconnects, and solid state trip relays. Schneider Electric cannot offer this.  Would you be open to having circuit breakers instead of fusible disconnects?  If so, will the branch circuit breaker need to be 100% rated?  We can offer 100% on the main breaker no problem, but we can only offer 80% on the branch breakers with LSTG.

Solicitation No. - N° de l'invitation

EC016-132714/A

Client Ref. No. - N° de réf. du client

R.043939.001

Amd. No. - N° de la modif.

018

File No. - N° du dossier

PWB-2-35125

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

---

**Answer:** The main switchboard and panel 'P' is to be fusible to control and minimize arc flash level, short circuit and co-ordination. The main fused disconnect is to have solid state L.S.I. and GFI capabilities.