

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
#910, 410-22nd Street East  
Saskatoon  
Sask.  
S7K 5T6  
Bid Fax: (306) 975-5397

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services  
Canada/Réception des soumissions Travaux publics et  
Services gouvernementaux Canada  
#910, 410 - 22nd Street East  
Saskatoon  
Sask.  
S7K 5T6

<b>Title - Sujet</b> Portable Wash Pad	
<b>Solicitation No. - N° de l'invitation</b> 01R32-130386/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> 01R32-130386	<b>Date</b> 2013-02-27
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$STN-191-4590	
<b>File No. - N° de dossier</b> STN-2-35101 (191)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2013-03-04</b>	
<b>Time Zone</b> <b>Fuseau horaire</b> Central Standard Time CST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Gerstmar, Denise	<b>Buyer Id - Id de l'acheteur</b> stn191
<b>Telephone No. - N° de téléphone</b> (306) 975-8912 ( )	<b>FAX No. - N° de FAX</b> (306) 975-5397
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Agriculture & Agri-Food Canada Agroforestry Development Centre PO Box 760 #1 Government Road Indian Head SK S0G 2K0	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

01R32-130386/A

Client Ref. No. - N° de réf. du client

01R32-130386

Amd. No. - N° de la modif.

002

File No. - N° du dossier

STN-2-35101

Buyer ID - Id de l'acheteur

stn191

CCC No./N° CCC - FMS No/ N° VME

---

This solicitation amendment is for the following requirement; 01R32-130386/A .

**Question 2**

Does the pad floor need to be sloped? (to drain into the trough)

**Answer 2**

Yes

**Question 3**

Can there be a single trough down the center - between the pads?

**Answer 3**

Yes

**Question 4**

Is the wastewater tank underground - top at ground level - to accommodate flow of waste water from trough to tank?

**Answer 4**

Yes