

The following changes have been made to the Port Granby WWTP Issue for Tender Specifications:

| Section | Page | Article | Description |
|----------|------|---------|--|
| 43 41 23 | N/A | Header | Section title revised from "Stainless Steel Tanks" to "Stainless Steel Slurry Tank" |
| | 1 | 1.1.1 | Items removed |
| | 1 | 1.1.2 | Item added |
| | 4 | 2.2 | "2.2 Clarifier Effluent Tanks" removed |
| | 4 | 2.3 | "2.3 Filtered Effluent Tank" removed |
| | 4 | 2.4 | "2.4 RO Permeate Tank" removed |
| | 4 | 2.5 | "2.5 RO Concentrate Tank" removed |
| | 4 | 2.6 | "2.6 Slurry Tank" renumbered to 2.2 |
| | 4 | 2.2.1 | Slurry Tank Number revised from "TNK-08-01" to "ST-09600" |
| 46 35 10 | 6 | 2.11.1 | Revised "Provide TEXP main drive motors with..." to "Provide main drive motors with..." |
| | 7 | 2.12.7 | Revised "Provide TEXP electric motors for..." to "Provide electric motors for..." |
| | 8 | 2.14.1 | Revised "Provide local control panel (CSA approved for Class 1 Division 2) containing all necessary circuit breakers..." to "Provide local control panel containing all necessary circuit breakers..." |
| 46 45 10 | 1 | 1.1.2 | Replaced "gas fired heating system" with "electric heating system" |