

Questions and Answers

Port Granby Waste Water Treatment Plant

Solicitation No.: EQ139-131604

1. These field instrument devices are regularly applied in similar applications as specified in this project within the water and wastewater industry.

Please accept this request to provide Krohne magnetic flow meters; Krohne turbidity analyzer; and Pulsar Process Measurement ultrasonic level transmitters; Magnetrol capacitance level switches; and Winters pressure gauges & bi-metal thermometers for the Port Granby Water Treatment Plant Project, that are represented by our company. Since we are not named, we would like to have an opportunity to bid the product devices on the subject project on sections of your spec as follows:

ANSWER:

As noted in Clause 1.1.1 of Section 40 90 00, it is the Contractor's responsibility to select the equipment and instruments in the WWTP. Equipment/instruments that satisfy the requirements outlined in the specification will be accepted.

Please refer to General Instructions to Bidders R2710T (2012-07-16) GI16 (2007-05-25) Approval of Alternative Materials

1. When materials are specified by trade names or trademarks, or by manufacturers' or suppliers' names, the bid shall be based on use of the named materials. During the solicitation period, alternative materials may be considered provided full technical data is received in writing by the Contracting Officer at least ten (10) calendar days prior to the solicitation closing date. If the alternative materials are approved for the purposes of the bid, an addendum to the bid documents shall be issued.