

The following changes have been made to the Port Granby WWTP Issue for Tender Specifications:

Section	Page	Article	Description
26 25 00	N/A	N/A	Section added to specifications.
26 29 23	N/A	N/A	Section added to specifications.
28 31 01	31	3.2.3	Revised "Alarm initiating devices to be wired with multi conductor #18 R90 cables..." to "Alarm initiating devices to be wired with multi conductor #16 R90 cables"
40 05 23	1	1.2.2.1	Revised "Refer to Section 43 21 05 and Division 26 for detailed specifications and Actuator types respectively." To "Refer to Section 40 05 25."
40 90 00	Attachment 1-M Page 5	Part 6	Device Tag revised from AIT 01030 and 01040 to 01031 and 01041.
			Transmitter Enclosure revised from "Class 1 Div. 1 Grp. C, D (NEMA 7&4)" to "NEMA 4X".
			Electrical Class/Div/Group revised to "Unclassified".
	Attachment 1-O Page 4	Part 6	Device Tag revised from AIT 01030 and 01040 to AIT 01032 and 01042.
			Transmitter Enclosure revised from "Class 1 Div. 1 Grp. C, D (NEMA 7&4)" to "NEMA 4X".
			Electrical Class/Div/Group revised to "Unclassified".