

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions -
TPSGC
11 Laurier St./11 rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Construction Services Division/Division des services de
construction
11 Laurier St./11 Rue Laurier
3C2, Place du Portage
Phase III
Gatineau, Québec K1A 0S5

Title - Sujet Investigative & Tech. Lab Fit-Up	
Solicitation No. - N° de l'invitation EH900-122450/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client R.047856.002	Date 2012-02-17
GETS Reference No. - N° de référence de SEAG PW-\$\$FG-343-58271	
File No. - N° de dossier fg343.EH900-122450	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-02-23	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Cook, Kristin	Buyer Id - Id de l'acheteur fg343
Telephone No. - N° de téléphone (819) 956-6122 ()	FAX No. - N° de FAX (819) 956-8335
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CRTC Les Terrasses de la Chaudière 1 Promenade du Portage Gatineau, Quebec J8X 4B1	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EH900-122450/A

Client Ref. No. - N° de réf. du client

R.047856.002

Amd. No. - N° de la modif.

005

File No. - N° du dossier

fg343EH900-122450

Buyer ID - Id de l'acheteur

fg343

CCC No./N° CCC - FMS No/ N° VME

ADDENDUM N° 3

CRTC Computer Investigative and Technical Lab Fit-up

PROJECT NO. R.047826.002
Date: February 16, 2012
Page 1 of 2

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

GENERAL

- 1 Distance Between 2nd Floor Electrical Room and Rooftop
1. The distance between the 2nd floor electrical room and the rooftop dry cooler is approximately 42m.
- 2 Existing Panel LCS-1
1. Existing Panel LCS-1 is Federal Pioneer, No. NHDP, Type: 03-08029.
- 3 Distance from floor slab to ceiling slab.
1. The distance from the floor slab to the ceiling slab is approximately 4m.

SPECIFICATIONS

- 1 Section 26 16.02 Moulded Case Circuit Breakers
1. Add new article 2.1.2 as follows:
600 V\3Ø branch circuit breakers to have minimum 14kA symmetrical rms interrupting capacity rating.

DRAWINGS

- 1 Refer to drawing E3 – Power and Systems, New and Demolition Work
1. RPM stands for Rack Power Module.
2. Drawing Note 6 includes a back box only, typical for all security devices.
3. Provide new security junction box at grid line 43 for new glass shatter detector.
- 2 Drawing A2 Furniture Plan
1. All Furniture and Equipment Racks are not included in this Contract
- 3 Drawing A4 Power, Voice & Data
1. Replace the symbol GL found on drawing A4 at grid line 43 with symbol GS indicating a Glass Shatter Device (GS)