

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, 12th floor
800,rue Burrard, 12e étage
Vancouver
British Columbia
V6Z 2V8
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 2V8

Title - Sujet Existing Site Utilities Relocation	
Solicitation No. - N° de l'invitation EZ899-123360/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2012-05-11
GETS Reference No. - N° de référence de SEAG PW-\$PWY-020-6677	
File No. - N° de dossier PWY-1-34525 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-05-30	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ly, Ronny(PWY)	Buyer Id - Id de l'acheteur pwy020
Telephone No. - N° de téléphone (604) 666-0043 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Ferndale Institution, Mission, B	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-123360/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

003

File No. - N° du dossier

PWY-1-34525

Buyer ID - Id de l'acheteur

pw020

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande

Vous trouverez l'addenda n° 2 ci-joint.

Les autres conditions ne changent pas.

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.
THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

Addendum #2

1.) Questions received by PWGSC Contracting May 9, 2012;

1.) Question 1: Lawn Basin and Relocating Existing CB Leads

.1 On Sheets C1, it says to relocate the existing CB Lead and swale in 2 locations where the new 250mm PVC storm pipe is being placed. There are 3 drainage pipes shown that look like they each connects to a headwall. Can I assume that this drainage pipe and headwall are to be removed and that they will be replaced by the new storm pipe and lawn basins shown on Sheet C2?

Answer: Yes.

.2 Sheets C2 shows what appear to be two lawn basins, but they are not label. Lawn basins 3 and 4 are designated by "LB3" and "LB4" respectively, and are shown in bold black circle, indicating that they are a new structure the contractor is required to install. There are 2 other black circles which I am assuming are new lawn basins, one at the bottom left page at the end of the 250mm storm pipe, and one above it next to the building service connection. Can you please confirm if there are 4 lawn basins being installed or are there only 2?

Answer: The storm line from DMH 2 to west – tie in existing CB no man hole or LB required. West service connection to be furnished with 900mm diameter sump c/w solid cast iron lid and frame. Price for supply and installation to be included in tender price.
Only 2 lawn basins.

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.
THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

Addendum #2

2.) Question 2: Sanitary Pipe Length

.1 The sanitary utility sewage pipe specifications states the sanitary pipe is to be PSM Polyvinyl Chloride, SDR 35 which is a standard PVC SDR pipe. The specifications is calling for a nominal length of 6m, but the standard lengths that PVC pipe comes in is 4m. I don't know how critical it is to have the sanitary pipe come in 6m lengths, but after talking to some local suppliers, I was told that 6m lengths are typically available on larger pipe sizes.

.2 Because the pipe diameter is smaller, and the total length required is a small amount, 6m length pipe would have to be special ordered and it will cost more than the standard PVC pipe that is available in stock. Could you please confirm if the typical 4m length PVC piping will be acceptable or does it have to be 6m?

Answer: 4m length is acceptable.

3.) Question 3: Silt Fencing

.1 Sheet C8 which shows the siltation control measures has plan legend with the symbol for silt fencing (*an "x" with a line on each side*), but I do not see that symbol anywhere on the drawing. Can I assume that silt fencing will be needed around the ditch going from the north-east, and going around the temporary siltation pond, and ending at the south-west ditch?

Answer: Contractor to place silt fence such that silt water is contained on site and allows for his work to continue without hindrance.

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.
THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

Addendum #2

4.) Question 4 : Gravel Access Pad and Truck Wheel Wash

.1 Can I assume that the gravel access pad shown on Sheet C8 can be placed anywhere by the contractor or is there a preferred location? The plan view drawing does not show where these facilities should go. Only the temporary silt pond is shown.

Answer: Contractor to place gravel access pad and truck wheel wash where best suited to keep silt onsite and allow for works within the work area. Once Contractor has chosen location, must get approval from owner and engineer.

END OF ADDENDUM #2