

ATT. 11

Solicitation No. EQ754-123194/A

Project No. R.042826.001

Kitchener, ON - Extension of Control Equipment Room and Cell Additions

Q41: What access control system is existing at the facility?

The camera portion is Axis/Bosch/Genetec but the access control system is not clear.

A41: All access control is via direct observation. An officer looks to a (existing) CCTV monitor to see who has buzzed into the MCCP and the officer presses a button that drives the lock.