

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet General Purpose Bldg-N.B./N.S.	
Solicitation No. - N° de l'invitation EC016-123090/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client R.043958.001	Date 2012-04-11
GETS Reference No. - N° de référence de SEAG PW-\$PWB-007-3063	
File No. - N° de dossier PWB-1-34209 (007)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-05-10	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ellis-Herring , Alison PWB	Buyer Id - Id de l'acheteur pwb007
Telephone No. - N° de téléphone (506) 636-3908 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment Number Seven (7) is raised to include the following questions and answers.

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 7

QUESTIONS AND ANSWERS

Q1. Please specify a minimum window area for open workstations (for GI or GO) window area is not in the room data sheet.

A1. As per room data sheets, it indicates to refer to drawing for minimums. On the drawings there are a number of windows indicated in each area. Each window is 1.44m²

Q2. Renous existing light pole are too close to the foundation wall when we do the excavation please provide direction (are we to re-locate or remove)

A2. This would form part of the design, building mounted light to meet spec section lighting levels may be enough.

Q3. Springhill is the temporary road to the site to be built to a specific standard including paving at the end of the job or it is to be build for the contractor used only and the area is to be topsoil and seeded at the end of the day.

A3. The intent is the road way to be gravel and it will remain after construction.

Q4. On the A-1 and A-2 drawings send with the RFP note for the following devices include only conduit back to security cabinet do we included only for conduit installation all wiring and device by owner. Please confirm.

A4. Please read Terms of Reference Section 5.5.15, page 159 of 188.

Q5. Due to the geothermal do we have the option of going outside the temp. fence or all the wells have to be inside the construction fence.

A5. YES, all construction work still needs to be protected.

Q6. Is a public address system required in the buildings? (both buildings)

A6. YES both buildings. See Terms of Reference Section 5.5.15, see Room data sheets.

Q7. An intercom station is indicated on one of the drawings issued but what or where is it connected to? (both buildings)

A7. See Terms of Reference Section.5.5.16, refer to drawings for locations

Q8. Is CCTV required and what areas should be covered? Inside and outside. (both buildings)

A8. See Terms of Reference Section.5.5.17, refer to drawings for locations

Q9. Addendum 5 indicates that the heating system shall be geothermal. A conventional method of approaching geothermal heating is to meet a portion of the peak load (approximately 75%) with geothermal and provide peak heating with an alternate source of heat such as electric or gas. Since the peak load only occurs for a short period of time, the cost benefit of providing 100% of the heating load through geothermal is not generally attractive. Based on the above, can an alternate source of heat be used to meet 25% of the peak load and if so, is there a preferred source?

A9. Part of Design to provide solution