

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jaspe**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**  
**Bid Fax: (780) 497-3510**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jasper**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**

<b>Title - Sujet</b> Fire Alarm Inspection Services	
<b>Solicitation No. - N° de l'invitation</b> EW076-113841/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> EW076-11-3841	<b>Date</b> 2012-05-02
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$EDM-022-9343	
<b>File No. - N° de dossier</b> EDM-1-34007 (022)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-05-15</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Standard Time MST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Bogus-edm, Dolan	<b>Buyer Id - Id de l'acheteur</b> edm022
<b>Telephone No. - N° de téléphone</b> (780) 497-3546 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**This solicitation amendment has been raised to answer questions posed during the solicitation period:****1.0** Reference: Section 3.4.1

Please identify manufacturer and model number of the Fire Alarm system for the Aspen apartment.

**1.1** Mircom, FX 2000**2.0** Reference: Section 3.4.1

Please identify the type and number of fire alarm devices monitored by the system for the Aspen apartment.

**2.1** Approx 50**3.0** Reference: Section 3.4.1

Please identify the type of sprinkler system installed in the Aspen Apartments.

**3.1** Astra LFD**4.0** Reference: Section 3.4.1

Please identify the number of suites in the Aspen apartment.

**4.1** 36**5.0** Reference: Section 3.4.1

Please identify manufacturer and model number of the Fire Alarm system for the Residential units.

**5.1** No fire alarm systems only smoke detectors.**6.0** Reference: Section 3.4.1

Please identify the type and number of fire alarm devices monitored by the system for the Residential units.

**6.1** Some are hardwired, some are battery back up, about 310**7.0** Reference: Section 3.4.1

Please identify the number of suites for the Residential units.

**7.1** 310**8.0** Reference: Section 3.4.1

Please confirm that we will have full access to all suites in the Residential units.

**8.1** Access once security cleared.**9.0** Reference: Section 3.4.2

Please identify manufacturer and model number of the Fire Alarm system for the GOCB.

**9.1** Mircom FA-1000**10.0** Reference: Section 3.4.2

Please identify the type and number of fire alarm devices monitored by the system for the GOCB.

**10.1** Ceberus

**11.0** Reference: Section 3.4.2

Please identify the type of sprinkler system installed in the GOCB.

**11.1** Dry pipe**12.0** Reference: Section 3.4.2

Please identify the number of suites in the GOCB.

**12.1** Approx 25**13.0** Reference: Section 3.4.2

Please identify manufacturer and model number of the Fire Alarm system for the Residential units.

**13.1** No fire alarm systems in houses**14.0** Reference: Section 3.4.2

Please identify the type and number of fire alarm devices monitored by the system for the Residential units.

**14.1** 68, hardwired smoke detectors**15.0** Reference: Section 3.4.2

Please identify the number of suites for the Residential units.

**15.1** 68**16.0** Reference: Section 3.4.2

Please confirm that we will have full access to all suites in the Residential units.

**16.1** Once security cleared.**17.0** Reference: Section 3.4.2

Please identify manufacturer and model number of the Fire Alarm system for the Other.

**17.1** Edwards, Fireshield**18.0** Reference: Section 3.4.2

Please identify the type and number of fire alarm devices monitored by the system for the Other.

**18.1** N/A**19.0** Reference: Section 3.4.2

Please identify the type of sprinkler systems installed in the Other.

**19.1** Drypipe**20.0** Reference: Section 3.4.2

Please identify the number of suites in the Other.

**20.1** 16

Solicitation No. - N° de l'invitation

EW076-113841/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

edm022

Client Ref. No. - N° de réf. du client

EW076-11-3841

File No. - N° du dossier

EDM-1-34007

CCC No./N° CCC - FMS No/ N° VME

---

**21.0** Reference: Section 4.2.3

Please identify manufacturer and model number of the Fire Alarm system for the Trailer.

**21.1** Mircom FA-1008K

**All the information contained within this solicitation amendment will form part of the solicitation package.**