

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Kingston, ON - Pittsburgh Institut	
Solicitation No. - N° de l'invitation EQ734-131066/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.045087.001	Date 2012-08-31
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-2-35049 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-06	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hassell, Bob	Buyer Id - Id de l'acheteur pwl039
Telephone No. - N° de téléphone (416) 590-8270 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Correctional Service Canada Pittsburgh Institution Highway 15 Joyceville, ON K7L 4X9	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EQ734-131066/A
Client Ref. No. - N° de réf. du client
R.045087.001

Amd. No. - N° de la modif.
003
File No. - N° du dossier
PWL-2-35049

Buyer ID - Id de l'acheteur
pw1039
CCC No./N° CCC - FMS No./N° VME

QUESTIONS AND ANSWERS

Question 1

Spec section 01 91 00 refers to a System Commissioning Administrator (SCA). Who is responsible to carry the SCA?

Answer 1

This is provided by the Consultant.

Question 2

Spec Section 01 91 31 refers to a Commissioning Authority and makes no mention of the SCA. Is this the same role? If not, who is responsible to carry the Commissioning Authority ?

Answer 2

This is the responsibility of the GC and includes the standard commissioning of equipment supplied by the GC as well as training on that equipment.

Question 3

Will Volume Two of the specifications be available in full or will the missing sections (most of 26 ,27,28,31,32 and some of 33) be sent as a separate amendment?

Answer 3

Sent to Merx as a separate attachments.

Question 4:

Drawing number M-400 shows a scale of 1:100. Is this accurate?

ANSWER 4

Details 1, 2 & 3 to read 1:50. Detail 4-not to scale (NTS).

Question 5

Section 075100, page 12, item 2.5.4: calls for tapered roof insulation. Could you please confirm what slope is to be used (i.e. 1%, 2% etc.) as none is shown ?

Answer 5

Use a 2% slope for tapered roof insulation

Question 6:

Drawing M-101, Basement Plumbing details the CW, HW and HW recirc approaching the mechanical room, however, I cannot locate any further detail or schematic to indicate the continuation of the piping within the mechanical room.

Solicitation No. - N° de l'invitation
EQ734-131066/A
Client Ref. No. - N° de réf. du client
R.045087.001

Amd. No. - N° de la modif.
003
File No. - N° du dossier
PWL-2-35049

Buyer ID - Id de l'acheteur
pw1039
CCC No./N° CCC - FMS No./N° VME

Answer 6

Connect 65 DCW to 100 DCW in Mechanical Room. Connect 32 DHW to DHWT in Mechanical Room. Connect 20 DHWR to hot water recirc pump in Mechanical Room

Questions 7

Please advise the material for 2 windows at room 101 with the coiling security grilles. See attached drawing.

Answer 7

This frame is a 1-hr. fire-rated pressed steel frame with GL-1 glazing.

Question 8

Washroom Accessory - Fold down seats specified is also included in the shower manufacturer specifications. Please advise if grab bars and folding seats at showers are to be supplied by 10 28 00.

Answer 8

NORR confirms that shower SH-1 is specified with a seat and one stainless steel grab bar. Shower SH-2 does not have a seat or a grab bar. As per Division 22, contractors are to supply and install showers

Question 9

the Fire Alarm for the Pittsburg Institution. Can we run a relay to connect to the existing Siemens panel. You call for a network connection in section 28, 1.2.7

Answer 9

The existing network and graphic display are to be updated as per specifications. Provide required cards and modules as per specifications.

Question 10

The security system riser diagram (Drawing E-601 Detail 4) shows two CCTV cameras but there are no specifications included for CCTV. Is a CCTV system required? If so please provide specifications.

Answer 10

The CCTV cameras are provided by the Departmental Representative. The scope of this contract is the conduits, wiring and outlet boxes as indicated.

Question 11

Section 08 71 11 3.2.1 states that "All electronic and Security hardware specified herein including but not limited to SIP boxes, card readers, security software reader interfaces ... : Supplied and installed by Section 08 71 11 supplier. Section 28 13 00 Access control has also

Solicitation No. - N° de l'invitation

EQ734-131066/A

Client Ref. No. - N° de réf. du client

R.045087.001

Amd. No. - N° de la modif.

003

File No. - N° du dossier

PWL-2-35049

Buyer ID - Id de l'acheteur

pwl039

CCC No./N° CCC - FMS No./N° VME

been included. Is the intention that all access control equipment be supplied by Div 8? If not which items specifically are to be supplied by Div 8 and which by Div 28.

Answer 11

All access control products are to be supplied by Division 08 as per item 1.5.1 of specification section 28 13 00 Access Control, issued with Addendum 02.

