

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet 50 Bed Living Unit, Westmorland Ins	
Solicitation No. - N° de l'invitation EC016-130878/A	Amendment No. - N° modif. 012
Client Reference No. - N° de référence du client R.043929.001	Date 2012-09-11
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3101	
File No. - N° de dossier PWB-2-35024 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-19	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro 12 est soumise et comprend la modification numéro 12 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Modification numéro 12

1. DEVIS

Reference Specification Section 08 61 10 'Vinyl Windows':

Delete Specification Section 08 61 10, Part 2.2.5 and replace with text as follows:

“.5 Screens: to CAN/CGSB-79.1-M91, Type 2 heavy duty, Class A fixed, Style 1 aluminum screening, 18x14 mesh:

- .1 Baked enamel finish (colour to match frame)
- .2 Heavy duty S2 screen strength rating to AAMA/WDMA/CSA-101/ I.S.2/A440 and AAMA/WDMA/CSA-101/I.S.2/A440S1.
- .3 Screens to be secured in place with tamper resistant, security fasteners”.

2. DESSINS

Reference Drawings A-101, A-102 and A-401 to A-406: Window identification tags:

- on Grid Line U between grid 5 and 21, change W3 to W4 on level 1 and level 2.
- on Grid Line N between grid 3 and 5, change W4 to W3 on level 1 and level 2.
- on Grid Line N between grid 22 and 24, change W4 to W3 on level 1 and level 2.
- on Grid Line 5 between grid Q and U, change W3 to W4 on level 1 and level 2.
- on Grid Line 18 between grid C and E, change W4 to W3 on level 1 and level 2.
- on Grid Line 21 between grid N and R, change W3 to W4 on level 1 and level 2.
- on Grid Line N between grid 21 and 22, change W1 to W4, level 2 only.

3. QUESTIONS ET RÉPONSES

Q1: What is the size of the transformer with primary & secondary voltage ratings. Also, what are the specs on the cut-outs & lightning arrestors.

R1: Transformer size is noted on Drwg E-507. Cutouts and Lighting Arrestors are to be to NB Power standards.

Q2: What would be the procedure going forward in regards to the supplying of furniture for the 50 Bed Living Unit at the Westmorland Institution?

R2: No furniture supply in this Contract.

Q3: Drawings indicate no fencing between existing building and new building. Is this work subject to the same restrictions as any project within the general population of the prison?

R3: No fencing in the Contract.

Q4: Drawing C-103 indicates asphalt, gravel shoulder and sidewalk without any clear idea where one starts and the other stops. Please provide a drawing that identifies the locations and boundaries of those items; it is impossible to quantify and price without that information.

R4: All surface materials are shown on the drawings by shading and/or line weight delineation.

Q5: Are prior approvals required for the above noted project or is this a performance spec and alternate products will be considered at the shop drawing approval stage as long as it meets or exceeds the performance and quality of the product specified?

R5: This is a performance spec and alternate products will be considered at the Shop Drawing stage.

Q6: Will we be getting a list of approved manufacturers for the specified material? There are no model #'s anywhere so it's difficult for the suppliers to quote. Or is the intent to simply follow the written specification and any manufacturer will be accepted? i.e. fixtures, specialties, boilers, hydronic heaters, pumps, etc.

R6: This is a performance spec so there will be very few 'approved manufacturers'.

Q7: Drawings provided are to Nova Scotia Specs which use an isolated neutral. New Brunswick lines all have grounded neutral, a non grounded neutral will not meet NB Power specs. All lines in Dorchester Penitentiary, N.B are built to NB Power specs. Please review and clarify.

R7: All high voltage work to be to NB Power standards. Where there is a conflict between Contract Documents and NB Power standards, then NB Power standards prevail.

Q8: Is there any approved manufacturer list for the HVAC equipments, we have certain "based on product" manufacture but is there more ??

R8: This is a performance spec and items where an 'acceptable material' has not been specified will be at the discretion of the bidder. Bidder to allow for equipment provided to meet the performance criteria.

Q9: What type of pole top transformers make and model are required?

R9: This is a performance spec. Rating and voltage of transformer has been given. All high voltage installation has to be to NB Power standards.

Q10: In specifications section 27, item 2.5 it calls for Cat6 Outside plant cable, however does not specify a part number. To my knowledge such a OSP plant cable does not exist, can you please confirm this item and if Cat6 is required please provide a reference part number?

R10: Outside Fiber Optic cable is specified on detail 2/E505. Outside Plant cable of this type should be available.

Q11: On drawing E-505 several references are made to media converters but no specification is given on these items. Can you please provide a reference part number if these are required to be supplied by contractor?

R11: Media Converter specification is covered in Section 28 16 00.

Q12: Fiber optic patch cords are identified on drawing E-505 but no quantity is given or specifications on Fiber optic patch cord requirements. Can you please provide additional information on fiber optic patch cords such as reference part numbers and direction on how to determine quantity required?

R12: Fiber Optic patch cords are to be appropriate to the requirements of the racks & media converters. Quantity is sufficient to complete the installation plus 10% spares.

Q13: On drawing E-505 there are 2 - 12STR fiber optic cables shown, however in the specifications section these are not listed and are shown on the plans as OSP. Can you please confirm if these are required to be Outdoor rated or permitted to be Distribution type fiber optic cables? For the 12STR OM1 62.5uM fiber would part number B9B042 and for the 12STR OM3 50uM B9C042 would this be acceptable?

R13: Cables referred to are all to be Outdoor rated. Alternate type is not acceptable.

Q14: Refer to Drawing C-103: Note indicates "Existing access road to be upgraded." The limit of road upgrading is not clear on the drawing. Please provide a drawing that shows the extent of work on the road to be "upgraded".

Solicitation No. - N° de l'invitation

EC016-130878/A

Client Ref. No. - N° de réf. du client

R.043929.001

Amd. No. - N° de la modif.

012

File No. - N° du dossier

PWB-2-35024

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

R14: It is shown on C-105, Access Road Plan & Profile & Sections. Extents of asphalt, shoulders, and gravel should be clear enough to quantify on this drawing.