

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jaspe**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**  
**Bid Fax: (780) 497-3510**

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works and Government Services Canada**  
**Telus Plaza North/Plaza Telus Nord**  
**10025 Jasper Ave./10025 ave. Jasper**  
**5th floor/5e étage**  
**Edmonton**  
**Alberta**  
**T5J 1S6**

<b>Title - Sujet</b> Fencing Contractor	
<b>Solicitation No. - N° de l'invitation</b> EW038-131918/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> PWGSC 20131918	<b>Date</b> 2012-11-16
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-011-9601	
<b>File No. - N° de dossier</b> PWU-2-35277 (011)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-11-20</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Standard Time MST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Hugo (RPC), Tammey	<b>Buyer Id - Id de l'acheteur</b> pwu011
<b>Telephone No. - N° de téléphone</b> (780) 497-3917 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EW038-131918/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

pwu011

Client Ref. No. - N° de réf. du client

PWGSC 20131918

File No. - N° du dossier

PWU-2-35277

CCC No./N° CCC - FMS No/ N° VME

---

The attached changes in the tender documents are effective immediately.  
This addendum will form part of the contract documents. See attached.

**Specifications for:**

# **Private Family Visitation Containment**

Edmonton Institution  
Edmonton, Alberta

**Correctional Service Canada**

**PROJECT # R.058797.001**



**ADDENDUM #02**  
**November 16, 2012**

---

**Issued by HFKS Architects Inc.**

Addendum #02 comprises:

1. Architectural Text (Specifications): 1 pages

This Addendum makes amendments to the Tender Documents for the "Correctional Services Canada: **Private Family Visitation Containment**" project.

This Addendum forms part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all Work contained herein shall be included in the Contract Price. Items listed under the Specifications in this Addendum and having influence on the Drawings are so deemed to alter the Drawings. The amendments modify the Contract Documents as follows:

**1. ARCHITECTURAL TEXT**

**ITEM #1: REFERENCE: ARCHITECTURAL TENDER DRAWING #A101 – ARCHITECTURAL INFORMATION.**

- .1 Add GENERAL NOTES section to read:

1. All concertina wire to be in loops of 710mm diameter.

- .2 Revise keynote 2.1 to read as follows:

Existing 1800mm tall fence and components to be demolished and removed from site **including complete removal of fence post piles. Infill all voids remaining as a result of the removal of piles. Replace finished surface to match existing.**

**ITEM #2: REFERENCE: ARCHITECTURAL TENDER DRAWING #A103 – ELEVATIONS AND SECTIONS.**

- .1 Clarification as to the intent of Detail #5 "TYPICAL SECTION OF REINFORCED CONCRETE MOWING STRIP":

1. The top of the mowing strip does not require a flat portion as shown in the contract documents. It is acceptable to have the top of the mowing strip slope (at 2%) to a single high point in the middle such that water will still be shed from the mowing strip in either direction. The dimensions and required clearances as per the contract documents still govern.

**END OF ADDENDUM #02**