

Solicitation No. - N° de l'invitation  
E0224-133187/A  
Client Ref. No. - N° de réf. du client  
R.057680.001

Amd. No. - N° de la modif.  
001  
File No. - N° du dossier  
PWD-2-35176

Buyer ID - Id de l'acheteur  
pwd005  
CCC No./N° CCC - FMS No./N° VME

---

## ADDENDUM #1

\*\*\*\*\*  
THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE  
IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT  
DOCUMENTS.  
\*\*\*\*\*

### **SPECIFICATION:**

In the specifications, add new section 31 53 13 - Timber Cribwork, see attached.

In the specification, section 01 10 10 - General Instructions, delete clause 1.2.1.1 and replace with new clause, 1.2.1.1 to read:

*"Build-up of existing 6.1m wide cribwork to elevation of 2.25m above LNT. Complete ballasting of all cribwork and install reinforced concrete deck (minimum 250mm thick), wheelguard, wheelguard blocking, coping, cleats, mooring rings, ladders, fire stops, lighting poles, and fendering as shown on the drawings."*

### **DRAWINGS:**

On drawing C3, add the following notes:

Add note #9 to read: "Contractor to keep area behind marginal wharf clear of snow, ice, and unsuitable materials to elevation of crib seat."

Add note #10 to read: "Contractor to carry cost to distribute existing stockpiles on approach in the general area as directed by owner."

Add note #11 to read: "Upland area to be backfilled using the material stockpiled on Harbour Authority's lay down area."

On drawing C4, rename detail 2/4/4 from "Wharf Component Plan (Not Applicable Below Deck)" to "Wharf Component Plan"

On drawing C5, delete detail 1/5/5 and replace with new detail 1/5/5 as shown on Sketch SKA-01, see attached:

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.

\*\*\*\*\*