

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions -
TPSGC
11 Laurier St./11 rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Construction Services Division/Division des services de
construction
11 Laurier St./11 Rue Laurier
3C2, Place du Portage
Phase III
Gatineau, Québec K1A 0S5

Title - Sujet FIRE ALARM/VOICE COMM SYS. REPLACE.	
Solicitation No. - N° de l'invitation EP067-133336/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client 20133336	Date 2013-05-02
GETS Reference No. - N° de référence de SEAG PW-\$\$FG-356-62581	
File No. - N° de dossier fg356.EP067-133336	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-05-07	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lagacé, Hélène	Buyer Id - Id de l'acheteur fg356
Telephone No. - N° de téléphone (819) 956-0060 ()	FAX No. - N° de FAX (819) 956-8335
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EP067-133336/A

Client Ref. No. - N° de réf. du client

20133336

Amd. No. - N° de la modif.

002

File No. - N° du dossier

fg356EP067-133336

Buyer ID - Id de l'acheteur

fg356

CCC No./N° CCC - FMS No/ N° VME

Amendment No. 2 is issued to:

1. to issue Addendum No. 2 & 3

Solicitation No. - N° de l'invitation

EP067-133336/A

Client Ref. No. - N° de réf. du client

20133336

Amd. No. - N° de la modif.

002

File No. - N° du dossier

fg356EP067-133336

Buyer ID - Id de l'acheteur

fg356

CCC No./N° CCC - FMS No/ N° VME

ADDENDUM NO. 2

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1. DRAWING E0-01 – Title Sheet, Electrical Legend and General Notes

.1 Add the following note to “General Notes – Special Access for Elevator Shaft / Transformer Vault, ETC.”

“.2 Elevator maintenance contractor is:
ThyssenKrupp Elevator Limited
1151 Parisien, Ottawa, Ont. K1B 4W4
Mike Dempsey Maintenance Manager
Tel# 613 731 0810 ext – 2610
Fax:(613) 731-3742”

.2 Existing flow and tamper switches are existing to remain. Replace modules as required, to ensure these devices will be ULC compatible with new fire alarm systems.

.3 New fire alarm system to be compatible with existing remaining components including wiring. Any extra cost due to incompatibility will be at the contractor's expense.

2. DRAWING E0-02 – New Fire Alarm Riser Diagram

.1 Note #10: “EXISTING LOOP #1 (ANALOGUE), CLASS B, HAS T-TAP. TRACE, LOCATE AND REMOVE T-TAP. PROVIDE NEW CONDUIT AND WIRING TO SUIT THE EXISTING CLASS OF WIRING.”

Exact location unknown, as indicated the contractor is to TRACE, LOCATE AND REMOVE T-TAP.

3. DRAWING E3-02 – Fire Alarm New Layout Parking Level Two

.1 Revise note relating to the “FIRE PUMP SUPERVISORY / FIRE ALARM MODULES” as follows:

FIRE PUMP SUPERVISORY / FIRE ALARM MODULES
MAINTAIN EXISTING LEVELS OF INTEGRATION BETWEEN THE FIRE PUMP SYSTEM & THE NEW FIRE ALARM PANEL PROVIDE VISUAL SIGNALS AT THE MAIN FIRE ALARM PANEL TO INDICATE: PHASE REVERSAL, PUMP RUNNING, LOSS OF POWER CONDITIONS.

4. DRAWING E4-05 – Fire Alarm Demolition Layout First Level

.1 At the lower left corner revise note as follows:

FIRE ALARM PANEL 'PARKING LEVEL P2 - FIRE PUMP & BOILER ROOM' RELOCATE
PANEL OVER DOOR EXTEND CONDUIT AND WIRING TO SUIT.

SPECIFICATION

1. SECTION 28 31 00 – Addressable Multiplex Fire Alarm and Voice Communication Systems

- .1 Revise paragraph 2. 7 - Telephone circuits for connection of remote emergency telephones are presently wired in Class B configuration to control unit and shall be re-used.
- .2 Revise paragraph 3.1.23.11 – “Means to communicate with telephones in elevator cars. Provide wiring to elevator controller locations for future connection to elevator telephones.”

Solicitation No. - N° de l'invitation

EP067-133336/A

Client Ref. No. - N° de réf. du client

20133336

Amd. No. - N° de la modif.

002

File No. - N° du dossier

fg356EP067-133336

Buyer ID - Id de l'acheteur

fg356

CCC No./N° CCC - FMS No/ N° VME

ADDENDUM NO. 3

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1. DRAWING E3 and E4 Series

- .1 The drawings indicate the existing mounting heights for the fire alarm pull stations. The fire alarm pull stations are to remain at the same mounting heights, unless indicated on the E3 series drawings.
- .2 E4 series DEMOLITION LAYOUT drawings represents the existing conditions and provides instructions to replace the devices, and to re-use the existing conduit and wiring. E3 series NEW LAYOUT drawings represents the new work. The quote is based on the documents as noted.

ALL OTHER TERMS AND CONDITIONS WILL REMAIN THE SAME.