

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> 50 Bed Living Unit, Westmorland Ins	
<b>Solicitation No. - N° de l'invitation</b> EC016-130878/A	<b>Amendment No. - N° modif.</b> 008
<b>Client Reference No. - N° de référence du client</b> R.043929.001	<b>Date</b> 2012-09-06
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-3101	
<b>File No. - N° de dossier</b> PWB-2-35024 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-09-13</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Cette modification de l'invitation numéro 8 est soumise et comprend la modification numéro 8 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

**Toutes autres conditions ne changent pas.**

## **Modification numéro 8**

### **1. DEVIS**

#### **1. Amend Specification Section 06 20 00, Section 3.6.1 to read:**

"1 Provide assembly and installation of custom-built millwork manufactured by Corcan and provided by owner for the following areas:

- .1 Residents Bedrooms
- .2 Residents Kitchens
- .3 Administration offices
- .4 Office Area Kitchens"

#### **2. Reference Specification Section 10 20 00, Part 2: Products:**

##### **Add section 2.4 to read:**

"2.4 Security Key Cabinet

- .1 Supply and install 32-position security key cabinet with Proximity Reader, Combined Cores, Keys, Interface, Key Rings & TPR Tool Set
  - .1 Ethernet enabled, Provide Network Drop & IP Address for each unit (See Electrical)
  - .2 Provide AC Power Supply - Power Requirements: 110 – 240 VAC, 47 – 63 Hz, 2 amps, 300 Watts
  - .3 Wiring / Cabling to be done by Corrections Canada
  - .4 Plywood for mounting boxes to be provided by Corrections Canada
  - .5 Limited 3 year warranty includes, parts, technical and software phone support.
  - .6 Contractor to confirm exact location of cabinet on site with Departmental Representative
  - .7 To be integrated into Global Facility Management Software
  - .8 Single Cabinet layout with one controller, cabinet must be mounted.
- .2 Acceptable Materials: Stanley Mechanical Solutions, Model(s):
  - .1 K1C2828B032G Key Systems Box for 32 positions – 1 req.
  - .2 2690154 Prox Reader for Above – 1 req.

.3 1CF72P1-626 Combined Cores for Above – 32 req.

.4 1AP12P1-7 Keys for above – 32 req.

.5 BAS-1320 Dual Interface Lenel Board – 1 req. (to be confirmed on site if there are no existing spare inputs on the existing boards to interface with the KSI Box)

.6 Global Facility Management Software

.7 Tamper proof key rings (TPR) 1 5/8" diameter – 34 req.

.8 TPR tool set containing one crimping and one closing tool – 1 req.

.9 APC Back-UPS Pro, 865 Watts/1500 VA, Input 120V /Output 120V, Extended runtime – 1 req

.10 1386-LGGMN Isoprox Cards, facility code and sequential number is required. – 200 req.

.11 B658AFS Total Access Cable, or B5502FE 22/4 Wire, B5300UE Shielded Wire, B5504FE 22/6 Wire. Quantity as required"

3. **Reference Specification Section 07 46 13 - Preformed Metal Cladding / Siding Panels**

**Amend Specification Section 07 46 13, Part 2.1.1.2 to read:**

".2 Colour: As selected by Departmental Representative from manufacturer's standard colour range"

**Amend Specification Section 07 46 13, Part 2.2.2 to read:**

".2 Colour: As selected by Departmental Representative from manufacturer's standard colour range"

4. **Specification Section 07 61 00 - Preformed Metal Cladding / Siding Panels**

**Amend Specification Section 07 61 00, Part 2.2.1 to add:**

".7 Acceptable Materials:

*.1 Manufacturer: VicWest, Model Tradition 100-4"*

5. **Amend Specification Section 01 10 10, Part 1.10.3 to read:**

".3 Obtain compliance certificates as prescribed by legislative and regulatory provisions of municipal, provincial and federal authorities as applicable to the performance of work.

*.1 Authority Having Jurisdiction:*

*Tantramar Planning District Commission*

*131H Main Street*

*Sackville*

*NB E4L 4B2*

*(506) 364 4754*

---

***Attn: Sterling Marsh, Building Inspector''***

6. **Reference Specification Section 31 11 00, @Excavating Trenching and Backfilling'**  
**Amend Specification Section 30 11 00, Part 3.6 as follows:**

Delete part 3.6.2 in it's entirety.

2. **DESSINS**

1. **Reference Drawing Number A-101.1**

Delete reference to 'Room 104B - Corridor' from item 1A - Finishes Schedule

Amend entry for 'Room 114 - Corridor' to show floor finish VT1

2. **Reference Drawing Number A-102**

Change Room Number Tag 'Corridor 227' to 'Corridor 219A'