

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Electrical Impr,McEacherns Pt, N.B.	
Solicitation No. - N° de l'invitation EC015-132262/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.058110.001	Date 2012-11-30
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3168	
File No. - N° de dossier PWB-2-35098 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-12-04	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. One (1) is raised to include the following Addendum No. One (1).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 1

DRAWINGS

THE CONTRACTOR IS TO SUPPLY, INSTALL AND COMMISSION ALL LABOUR AND MATERIALS TO COMPLETE THE FOLLOWING ADDITIONAL WORK:

<u>ITEM</u>	<u>REFERENCE</u>	<u>DESCRIPTION</u>
1.	DRAWING E2 OF 9	.1 RELOCATE WELDING OUTLET 9C ON RECEPTACLE SHROUD RS-9 TO RECEPTACLE SHROUD RS-1 AND CONNECT TO RELOCATED 50A, 2P CIRCUIT BREAKER ON CIRCUIT A-40,42 AND NAME 1C.
		.2 AT RECEPTACLE SHROUD RS-1, RELOCATE RECEPTACLE 1C AND 1D ON CIRCUITS A-6 AND A-8 TO RECEPTACLE SHROUD RS-9 AND RENAME RECEPTACLES 9C AND 9D ON CIRCUITS B-5 AND B-7 AND CONNECT TO RELOCATED GFI CIRCUIT BREAKERS FROM RS-1.
		.3 NOTE 10 ENCLOSURE TO BE EEMAX 4X TYPE.
		.4 NOTE 33 TO APPLY TO WIRING BETWEEN PB AND P11 ON WHARF 404.
		.5 NOTE 14 TO APPLY TO UNDERGROUND CIRCUITS BETWEEN PANEL A AND P6/RS-2 ON WHARF 402.
		.6 NOTES 17, 18, 19, 20 AND 21 TO APPLY TO UNDERGROUND CONDUITS BETWEEN PANEL A AND RS-3 ON WHARF 402.

Solicitation No. - N° de l'invitation

EC015-132262/A

Client Ref. No. - N° de réf. du client

R.058110.001

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWB-2-35098

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

.7 SUPPLY AND INSTALL A 27mm PVC CONDUIT AND 2#4RW90 PLUS 1#8 GROUND FROM NON-METERED SERVICE NS-1 AT RAMP 502, UNDERGROUND FIFTEEN (15) METERS TO THE EAST, TO THE EEMAX 4X JUNCTION ON THE BACK OF THE WASTE OIL BUILDING AND CONNECT CIRCUIT A-31 FROM NS-1 TO THE EXISTING LIGHTS AND ALARMS IN THE WASTE OIL BUILDING.