

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Fencing Contractor	
Solicitation No. - N° de l'invitation EW038-131918/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client PWGSC 20131918	Date 2012-11-13
GETS Reference No. - N° de référence de SEAG PW-\$PWU-011-9601	
File No. - N° de dossier PWU-2-35277 (011)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-11-20	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hugo (RPC), Tammey	Buyer Id - Id de l'acheteur pwu011
Telephone No. - N° de téléphone (780) 497-3917 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EW038-131918/A

Amd. No. - N° de la modif.

001

Buyer ID - Id de l'acheteur

pwu011

Client Ref. No. - N° de réf. du client

PWGSC 20131918

File No. - N° du dossier

PWU-2-35277

CCC No./N° CCC - FMS No/ N° VME

The attached changes in the tender documents are effective immediately.
This addendum will form part of the contract documents. See attached.

Specifications for:

Private Family Visitation Containment

Edmonton Institution
Edmonton, Alberta

Correctional Service Canada

PROJECT # R.058797.001



ADDENDUM #01
November 9, 2012

Issued by HFKS Architects Inc.

Addendum # 01 comprises:

- | | |
|---|---------|
| 1. Architectural Text (Specifications): | 3 pages |
| 2. Pre-tender Site Meeting Notes | 2 pages |

This Addendum makes amendments to the Tender Documents for the "Correctional Services Canada: **Private Family Visitation Containment** " project.

This Addendum forms part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all Work contained herein shall be included in the Contract Price. Items listed under the Specifications in this Addendum and having influence on the Drawings are so deemed to alter the Drawings. The amendments modify the Contract Documents as follows:

1. ARCHITECTURAL SPECIFICATIONS

**ITEM #1 REFERENCE: ARCHITECTURAL TENDER DRAWING #A101 –
ARCHITECTURAL INFORMATION.**

- .1 Revise the following keynotes to read as follows:

1. Revise keynote 2.5 to read:

Remove grass and 200mm soil to allow for new 200mm compacted "road crush" gravel. **Maintain slope for drainage away from the private family visitation buildings.**

2. Delete keynote 5.9:

Delete:

~~Typical 19ga. tie wire. 300mm on center minimum~~

Revise to read:

Typical 6ga. tie wire. 300mm maximum on center.

3. Delete keynote 10.2 and revise as follows:

Delete:

~~3028 high X 1200mm wide wire mesh fence gate with barbed concertina wire. Wire mesh to match the fence the gate is mounted on. Framing members to be 34mm dia. Gate to have a pad lock.~~

Revise to read:

3028 high X 1200mm wide wire mesh fence gate with barbed concertina wire. Wire mesh to match the fence the gate is mounted on. Framing members to be 43mm dia. Gate to have a pad lock.

4. Delete keynote 10.5 and revise as follows:

Delete:

~~1800mm high X 1200mm wide wire mesh fence gate. Wire mesh to match the fence that the gate is mounted on. Framing members to be 34mm dia.~~

Revise to read:

1800mm high X 1200mm wide wire mesh fence gate. Wire mesh to match the fence that the gate is mounted on. Framing members to be 43mm dia.

2. PRE-TENDER SITE MEETING NOTES

ITEM #1 PRE-TENDER SITE MEETING NOTES

1. Attached as an INFORMATION DOCUMENT are the meeting notes from November 09, 2012 Pre-Tender Site Meeting.

END OF ADDENDUM #01

Item	Topic	Discussion	Action by
------	-------	------------	-----------

NOTE! These Meeting notes are accepted by all parties as distributed subject only to any changes or corrections that may be agreed and noted as a result of today's meeting.

Section 1.0	Site Walkthrough
-------------	------------------

- | | |
|-----|--|
| 1.1 | The contractor who was on site for this meeting was able to walk through the site. |
|-----|--|

Section 2.0	Questions From Attending Contractor
-------------	-------------------------------------

- | | | |
|-----|---|------|
| 2.1 | Clarification is requested on electrical scope:

There is an existing cable (keynote 16.1, Glass Break/Fire Alarm) that runs from the west perimeter fence to the east along the top of the fence that separates the backyards of the two private family visitation yards and enters into the north building on the south side of the building. Because of a gate being installed in the above noted fence the cable has to be moved to underground (as per the contract documents). The cable is to be placed in a conduit under the ground thus will have to be disconnected and either replaced or reinstalled. | INFO |
| 2.2 | Question is asked as to the depth of the existing fence post piles that are to be removed?

The depth of the existing fence post piles is unknown. | INFO |
| 2.3 | There is brief discussion as to phasing for winter construction.

As a point of clarification to all bidders, the project is to be bid based upon the criteria contained in the contract documents and bid documents, including the start and finish date for the Work. | INFO |
| 2.4 | Who is responsible for locating buried services?

The general contractor will be responsible for the location of all buried services. | INFO |
| 2.5 | There is a brief discussion pertaining to the 2 new fence extensions that are to meet up with the existing perimeter fence.

This new fence that is to meet the existing exterior perimeter fence is to do so at the location of an existing fence post of the perimeter fence. | INFO |
| 2.6 | Clarification is requested as to the landscaping scope.

Where indicated in the contract documents there is to be 200mm of grade removed from site and replaced with compacted gravel. The grade under the gravel is to maintain positive drainage away from the private family visitation containment buildings. | INFO |