



Public Works and
Government Services Canada
Travaux publics et
Services gouvernementaux Canada

DIALOG™

04	ADDENDUM #1	2012-09-28
03	TENDER	2012-08-21
02	99% REVIEW TO PWGSC	2012-07-20
01	66% REVIEW TO PWGSC	2012-05-17
revision		date

Do not scale drawings.
Verify all dimensions and conditions on site and immediately
notify the Departmental Representative of all discrepancies.

project title
titre du projet
JOYCEVILLE
JOYCEVILLE PENITENTIARY BUILDING J3 RENO
3766 HWY 15
JOYCEVILLE
Ontario

drawing title
titre du dessin
PANEL SCHEDULES

drawn by
dessine par
OS

designed by
conc par
NC

approved by
approuve par
NA

bid
offre
project manager
administrateur
de projets

project date
date du projet
2012-08-21

project no.
no. du projet
DIALOG NO. 09732T01
R.052025.001

drawing no.
dessine no.
E-03

NOTES

1. ACCESS PANELS ARE REQUIRED FOR ALL JUNCTION BOXES IN AREAS WITH DRYWALL CEILING. COORDINATE
WITH ARCHITECTURAL AND MECHANICAL SECTIONS.

PANEL IDENTIF: RP-E3A	LOCATION: CORRIDOR 200	SERVICE: 208Y/120V, 3ø, 4W
FED FROM: 30A DISC. SWITCH	MOUNTING: SURFACE	MAIN CCT. BRK: 30 AMPS
REF. DWG: E-31	MAINS:	
LOAD DESCRIPTION	WATTAGE øA øB øC	BRK AMP
LIGHTING	1024	15
WALL RECEPTACLES 6		15
WALL RECEPTACLES 4		15
COUNTER RECEPTACLE		20
COUNTER RECEPTACLE		20
FRIDGE		15
COPIER		20
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
MICROWAVE		15
		15
TOTAL LOAD CONNECTED:		WATTS

PANEL IDENTIF: RP-E3A1	LOCATION: CORRIDOR 300	SERVICE: 208Y/120V, 3ø, 4W
FED FROM: 30A DISC. SWITCH	MOUNTING: SURFACE	MAIN CCT. BRK: 30 AMPS
REF. DWG: E-32	MAINS:	
LOAD DESCRIPTION	WATTAGE øA øB øC	BRK AMP
LIGHTING	1024	15
WALL RECEPTACLES 6		15
WALL RECEPTACLES 3		15
WALL RECEPTACLES 2		15
WALL RECEPTACLES 2		15
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
		15
		15
		15
		15
		15
TOTAL LOAD CONNECTED:		WATTS

PANEL IDENTIF: RP-E3A2	LOCATION: OFFICE 404	SERVICE: 208Y/120V, 3ø, 4W
FED FROM: 30A DISC. SWITCH	MOUNTING: SURFACE	MAIN CCT. BRK: 30 AMPS
REF. DWG: E-33	MAINS:	
LOAD DESCRIPTION	WATTAGE øA øB øC	BRK AMP
LIGHTING	1088	15
WALL RECEPTACLES 5		15
WALL RECEPTACLES 4		15
WALL RECEPTACLES 3		15
WALL RECEPTACLES 2		15
COPIER		20
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
		15
		15
		15
TOTAL LOAD CONNECTED:		WATTS

PANEL IDENTIF: RP-E3A3	LOCATION: SPACE 500	SERVICE: 208Y/120V, 3ø, 4W
FED FROM: 30A DISC. SWITCH	MOUNTING: SURFACE	MAIN CCT. BRK: 30 AMPS
REF. DWG: E-34	MAINS:	
LOAD DESCRIPTION	WATTAGE øA øB øC	BRK AMP
LIGHTING	960	15
WALL RECEPTACLES 6		15
WALL RECEPTACLES 1		15
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
MECHANICAL CONTROLS		15
AHU-1 LIGHTING		15
GLYCOL FEED TANK		15
CONTROL PANEL		15
MOTORIZED DAMPERS		15
MOTORIZED DAMPERS		15
		15
TOTAL LOAD CONNECTED:		WATTS