

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> 50 Bed Living Unit, Westmorland Ins	
<b>Solicitation No. - N° de l'invitation</b> EC016-130878/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> R.043929.001	<b>Date</b> 2012-08-29
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-3101	
<b>File No. - N° de dossier</b> PWB-2-35024 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-13</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Tender Amendment Number 4 is raised to include the following **Addendum No. 4.**

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

## **Addendum No. 4**

### **DRAWINGS**

#### **1. Reference Drawing E-002:**

- 1 Add one 27mm Rigid PVC conduit for PPA system to section B-B from New 50 Bed Living Unit Building to Building F-58.

#### **2. Reference Drawing E-300:**

- 1 Add one L5-15R twistlock receptacle in Lan. Room 004 mounted to suit Senstar PPA receiver. Wire receptacle to panel EM circuit #57.

#### **3. Reference Drawing E-301:**

- 1 Add one L5-15R twistlock receptacle in Janitors Closet 121 mounted to suit Senstar PPA receiver. Wire receptacle to panel EM circuit #59.

#### **4. Reference Drawing E-302:**

- 1 Add one L5-15R twistlock receptacle in Mech/Elect N210 mounted to suit Senstar PPA receiver. Wire receptacle to panel EM circuit #61

#### **5. Reference Drawing E-400:**

- 1 Provide and install PPA (Personal Protection Alarm) receiver in Lan. Room 004 c/w 2C18 AWG twisted pair + #12B in 21mm(3/4)C back to Security Cabinet in Lan Room 004. PPA receivers shall be purchased from Senstar-Stellar Ottawa, Ontario.

#### **6. Reference Drawing E-401:**

- 1 Add one supervised valve and one flow switch to second range in Kitchen E114
- 2 Provide and install PPA (Personal Protection Alarm) receiver in Janitors Closet 121 c/w 2C18 AWG twisted pair + #12B in 21mm(3/4)C back to Security Cabinet in Lan Room 004. PPA receivers shall be purchased from Senstar-Stellar Ottawa, Ontario.

---

**7. Reference Drawing E-402:**

- Add two exterior PTZ (Pan/Tilt/Zoom) cameras to roof above on outer corners of building Grid Lines 8/A 18/A. Refer to 4/E505 for wiring.
- 2 Provide and install PPA (Personal Protection Alarm) receiver in Mech/Elect N210 c/w 2C18 AWG twisted pair + #12B in 21mm(3/4)C back to Security Cabinet in Lan Room 004. PPA receivers shall be purchased from Senstar-Stellar Ottawa, Ontario.

**8. Reference Drawing E-505:**

- 1 Supply and install 25pr security cable + #12B in 27mmC from Security Electronics Equipment Cabinet to Existing Senstar equipment in building F-58. Provide and install all necessary hardware, receivers, programing, etc. for existing Senstar system in building F-58 to be expanded for new equipment.

**9. Reference Drawing E-507:**

- 1 Revise incoming secondary feeders from 8#600 KCMIL RW90 to 8#750 KCMIL RW90.

**10. Reference Drawing E-601:**

- 1 Add three 15A/1P breakers to panel EM circuits 57,59 and 61. Label as PPA Receives.

**11. Reference Drawing C-103**

- 1 Drawing C-103 Grading Plan is reposted as ATT 4 (DSP Eng.).