

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet 50 Bed Living Unit, Westmorland Ins	
Solicitation No. - N° de l'invitation EC016-130878/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client R.043929.001	Date 2012-08-31
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3101	
File No. - N° de dossier PWB-2-35024 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-13	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro 5 est soumise et comprend la modification numéro 5 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Modification numéro 5

1. DEVIS

Section 01 50 00 Temporary Facilities

- .1 Amend specification section 01 50 00, Part 1.6.1 to read:
Provide Temporary Fence to enclose the construction area of work site

Section 01 79 00 Demonstration and Training

- .1 Amend specification section 08 71 00, to add Part 1.5.3 to read:
1.5.3 Contractor to keep records of all personnel who attend training and demonstration sessions. Lists to be submitted to Departmental Representative on completion of training

Section 08 71 00 Hardware / Keying clarification

- .1 Amend specification section 08 71 00, Part 2.1.1.7 to read:
Mortise and Rim Cylinders: Best 7-pin type, type G keyway for inmate areas, type H keyway in secure areas
- .2 Amend specification section 08 71 00 Part 2.6 as follows:
Hardware groups #1, #2, #3, #6, #7, #8, #11, #13, #14, #15, #17, #19, #22
CYLINDER Best 7-pin, type G keyway
Hardware Groups #4, #5, #9, #10, #12, #16, #18, #20, #21
CYLINDER Best 7 pin, type H keyway

Section 21 05 01 Common Work Results for Mechanical

- .1 Amend Specification Section 21 05 01, Part 1.1.5.3.6 to read
.6 Valves Schedule and flow diagram for all sizes, types and locations of valves

Section 21 05 05 Common Work Results for Fire Suppression

- .1 Amend Specification Section 21 05 01, Part 1.1.6.3.6 to read
.6 Valves Schedule and flow diagram for all sizes, types and locations of valves

Section 26 05 00 Common Work Results for Electrical General

- .1 Add sentence in Part 1.3, Design Requirements to read:
.4 High-Voltage systems to be designed and installed in accordance with NB Power standards. Where conflict exists between High Voltage details shown on the contract drawings and NB Power standards, the NB Power standards shall prevail

Section 99 99 98 List of Drawings

- .1 Amend description of drawing C-104 to read

C-104 Plan and Profile Sprinkler Watermain STA 1 +000 to 1 +340

Amend description of drawing C-106 to read:

C-106 Construction Details

2. **DESSINS**

Reference Drawing Number S-403

- .1 Revise Note # 2 on Drawing S-403 to read as follows:
Bottom Chord of all steel joists and timber trusses to be designed to carry an additional concentrated Live Load of 2kN at any location between panel points full length of joist/truss.

Reference Drawing Number E-001

- .1 Revise overhead high voltage and fibre line extension as indicated on attached electrical sketch ESK-01

Reference Drawing Numbers E-004, 005 & 006

- .1 Where conflict exists between High Voltage details on contract drawings and NB Power standards, the NB Power standards shall prevail

Reference Drawing Number E-505, Detail 4

- .1 Electrical contractor to engage the services of Marcomm or Senstar to make final connections for video surveillance equipment to the existing security system. Provide all necessary programming as required.