

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet EMSI-GI-GO Building	
Solicitation No. - N° de l'invitation EW038-123226/A	Amendment No. - N° modif. 009
Client Reference No. - N° de référence du client CSC	Date 2012-05-08
GETS Reference No. - N° de référence de SEAG PW-\$PWU-909-9348	
File No. - N° de dossier PWU-1-34831 (909)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-05-31	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mayhew (RPC), Sylvia	Buyer Id - Id de l'acheteur pwu909
Telephone No. - N° de téléphone (780) 497-3645 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EW038-123226/A

Client Ref. No. - N° de réf. du client

CSC

Amd. No. - N° de la modif.

009

File No. - N° du dossier

PWU-1-34831

Buyer ID - Id de l'acheteur

pwu909

CCC No./N° CCC - FMS No/ N° VME

This Amendment #9 is raised to provide the following clarification regarding **Section M - Mechanical of the Project Manual and to the allowance of Roof top units.**

A1. Reference to CSC Technical Consideration Section M was deleted in Amendment #1. Roof top units are still not permitted, due to the sloped roof requirement identified in Turnkey Project Manual Article 4.1.5 of Section 3 - Performance Specifications and Article 7.0 - Mechanical Performance Specifications.

END OF AMENDMENT