

Part 1 ADDENDUM NO.1

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

1.2 Smoke Detectors

- .1 All existing smoke detectors to be removed and replaced with the following unit:
 - .1 New Smoke detectors to be Kidde Model P1276CA, Hard Wired Smoke Alarm with Front Load Battery Door, 120V AC direct wire.
- .2 Final location as per drawings for cells as per existing drawings.

END OF SECTION