
ADDENDUM #1

THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE
IMMEDIATELY. THE ADDENDUM SHALL FORM A PART OF THE CONTRACT
DOCUMENTS.

In the specifications, Section 15 49 10, delete Clause 1.16
Electrical Requirements in its entirety and replace with new
Clause 1.16 to read;

1.16 Electrical Requirements

- .1 Electrical power is available at the site for connection in a pull pit located on the concrete pad. The Contractor shall be responsible for all cost associated with connection and disconnection to this service.
- .2 The existing available power on site for the Contractor's use is 600 volt, 3 phase, 60 amp service. All contractor supplied equipment shall not exceed this available service.
- .3 The power supply connecting/disconnecting work shall be done by a qualified journeyman electrician.
- .4 Controls: to Nema 4 factory wired. Enclosed in Electrical and Electronic Manufacturers' Association of Canada (EEMAC) 1 steel cabinet, mounted internally in electrical process room of trailer. All electrical, computer or instrumentation wiring entering the treatment area of the trailer shall have intrinsically safe cable connections.

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.

All other terms & conditions remain unchanged.
