


Ground Penetrating Radar Survey 1:200

LEGEND GPR SURVEY

- Sanitary sewer
- Storm sewer
- Unverified underground target/anomaly
- 3D GPR coverage
- Clean out/floor drain

NOTE:  
It is recommended to verify the true nature of the marked utilities by chipping or hand excavating. Due diligence must be exercise when excavating. GPR survey was carried out where no obstruction was on site during the time of the survey.  
The anomalies may have been caused by saturated soil, existing pipe or buried manmade structure.  
No utility was found at B2 level . Hatched area represents location with no access.  
Scale is approximate.



terraprobe geoscience corp.  
4650A dawson st.  
burnaby b.c.  
canada, V5C 4C3  
tel: 604 291 9391  
fax: 604 648 8118  
email: gpr@terraprobe.com  
web: www.terraprobe.com

The total aggregate liability of Terraprobe arising from professional acts, errors or omissions shall not exceed the total fees for the services rendered and Terraprobe shall have no other liability, obligation or responsibility of any kind for losses, costs, expenses or other damages (including without limitation special, indirect, incidental or consequential damages) relating to services or results provided by Terraprobe. All results provided by Terraprobe are strictly for the use of the Client, and Terraprobe shall not be responsible for any reliance on or any use or interpretation of such results by third parties. Terraprobe shall not be responsible for any loss, damage or liability arising from any acts by the Client, its agents or staff or other consultants employed by the Client.

Public Works Government Services Canada

Ground Penetrating Radar  
Survey Results  
Sinclair Center  
757 Hastings St., Vancouver, BC

GPR-01

by Terraprobe Geoscience Corp.

Peter Takacs Oct. 2012 TG# 641