

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canadian Standards Association (CSA International)
.1 CSA C22.1, Canadian Electrical Code, Part 1 (Latest Edition), Safety Standard for Electrical Installations.
.2 CAN/CSA-C22.3, Latest Edition, Overhead Systems.
.3 CAN3-C235, Latest Edition, Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC)
.1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
- .3 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
.1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.
- 1.2 DEFINITIONS .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.
- 1.3 DESIGN REQUIREMENTS .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
.1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates and labels for control items in English.
-

- 1.4 SUBMITTALS .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop drawings:
- .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia, Canada.
 - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.
 - .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
 - .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
 - .5 Submit required number of copies of Drawings to authority having jurisdiction.
 - .6 If changes are required, notify Departmental Representative, Consultant of these changes before they are made.
- .3 Quality Control: in accordance with Section 01 45 00 - Testing and Quality Control.
- .1 Provide CSA certified equipment and material.
 - .2 Where CSA certified equipment and material is not available, submit such equipment and material to authority having jurisdiction for special approval before delivery to site.
 - .3 Submit test results of installed electrical systems and instrumentation.
 - .4 Permits and fees: in accordance with General Conditions of contract.
 - .5 Submit, upon completion of Work, load balance report as described in PART 3 - LOAD BALANCE.
 - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
- 1.5 QUALITY ASSURANCE .1 Quality Assurance: in accordance with Section 01 45 00 - Testing and Quality Control.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians who
-

- 1.5 QUALITY ASSURANCE (Cont'd)
- .2 Qualifications:(Cont'd)
hold valid Master Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Act respecting manpower vocational training and qualification.
 - .1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.
 - .2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.
 - .3 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 28 - Health and Safety Requirements.
- 1.6 DELIVERY, STORAGE AND HANDLING
- .1 Material Delivery Schedule: provide Consultant with schedule within 2 weeks after award of Contract.
 - .2 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- 1.7 SYSTEM STARTUP
- .1 Instruct operating personnel in operation, care and maintenance of systems, system equipment and components.
 - .2 Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.
 - .3 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant will aspects of its care and operation.
-

1.8 OPERATING
INSTRUCTIONS

- .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
- .2 Operating instructions to include following:
 - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
 - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
 - .3 Safety precautions.
 - .4 Procedures to be followed in event of equipment failure.
 - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.

1.9 Addenda and
Revisions

- .1 All addenda, instructions and revisions issued during the tendering period shall become part of the Contract Documents and shall be included in the Tender, and shall take precedence over previous instructions.
- .2 The Owner and Engineer reserve the right to make revisions to the drawings during the period of construction and these revisions shall take precedence over previously issued drawings. All revisions to work shall be executed by duly authorized change orders with the amount of addition or deduction to the contract amount approved by the Owner before the execution of any work entailed in the revisions.

1.10 Substitutions

- .1 It is the intent of these drawings to establish the required quality of materials. Where manufacturers names or catalogue references are used, it is done in order to establish the required quality, style, size or function. Products of other manufacturers will not be permitted after the signing of the contract. The decision as to suitability shall rest with the Engineer.
- .2 Should the Contractor propose to furnish material and equipment other than those

1.10 Substitutions .2
(Cont'd)

(Cont'd)
specified, he shall submit a written request for any or all substitutions prior to the tender closing date. Such a request shall be accompanied by a complete description including manufacturer, brand name, catalogue number, and technical data for all items. If requested by the Engineer, the Contractor shall submit for inspection a sample of the proposed item.

- .3 All material not meeting the standards as set down by these specifications shall not be allowed on the job site.
- .4 Substitutions affecting the design will not be permitted. Additional costs to any other trade as a result of a change or substitution by this Contractor, shall be borne by this Contractor.
- .5 The listing of a manufacturer as acceptable does not imply acceptance of all products of that manufacturer and only products meeting the standards as set out in the specifications will be accepted.

1.11 Scope of Work .1

The Electrical Contractor shall furnish all labour, materials, tools, appliances and equipment to entirely complete and provide for the operation of the electrical systems.

- .2 The overall intention is to provide for a finished piece of work complete in all aspects, and all items reasonably inferrable as called for by the plans and specifications, and by normally accepted good practice, notwithstanding that every item necessarily required may not be particularly mentioned. This Contractor shall fulfill his obligation and not take advantage of any unintentional errors or omissions should such exist, to the detriment of the Owner's interest. The work shall include but not be limited to:
 - .1 Power Distribution
 - .2 Branch Circuit Wiring
 - .3 Removals and installation of recessed boxes for devices.
 - .4 Cell Lighting Replacement

- 1.11 Scope of Work (Cont'd) .2 (Cont'd)
.5 (Cont'd)
.5 Communications systems relocations
.6 Fire Alarm system relocations
- 1.12 Electrical Drawings .1 The drawings which constitute an integral part of this contract shall serve as working drawings. They indicate the general layout of the complete electrical system; arrangements of feeders, circuits, outlets, switches, panelboards, etc.
.2 Field verification of scale dimensions on plans is directed since actual locations, distances, and levels will be governed by the field conditions.
.3 All discrepancies related to the electrical work shall be promptly brought to the attention of the Engineer for clarification.
- 1.13 Examination of Drawings and Existing Conditions .1 The Electrical Contractor shall become completely familiar with the drawings and specifications, as well as construction methods of other trades related to his work to avoid possible conflicts on the project. Should drastic changes be necessary to resolve such conflicts, this Contractor shall notify the Engineer and secure written approval and agreement on necessary adjustments before the installation is started.
.2 Before submitting his tender, this Contractor shall visit the site and become familiar with site conditions, availability of storage space and all other factors that might influence his tender.
.3 The Contractor shall determine all working conditions and rigidly comply. Conditions requiring special consideration include but not be limited to:
.1 Dust.
.2 Noise.
.3 Vibration.
.4 Water.
.5 Use of powder actuated tools.
.6 Working hours.
-

- 1.13 Examination of Drawings and Existing Conditions (Cont'd) .3 (Cont'd)
- .7 Access to working locations.
 - .8 Continuity of power.
 - .9 Project schedule.
 - .10 Physical protection of Owner's facility and equipment.
- .4 No extras will be allowed due to failure to take site conditions into consideration.
- .5 The exact roughing-in dimensions and connection points shall be determined from shop drawings and on-site measurements.

- 1.14 Discrepancies .1 Bidders in preparing their tenders, finding any errors, omissions, or discrepancies in the plans, specifications or other documents, or having any doubt in the intent or meaning of any part thereof, shall immediately notify the Engineer, who will send written instructions or clarification to all bidders. Where such discrepancies exist and it is evident that this Contractor could not have properly tendered without clarification and where such clarification was not requested, no extra to the contract will be considered in order to have the installation properly made. The Owner and Engineer will not be responsible for oral instruction.

PART 2 - PRODUCTS

- 2.1 MATERIALS AND EQUIPMENT .1 Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Material and equipment to be CSA certified. Where CSA certified material and equipment are not available, obtain special approval from authority having jurisdiction before delivery to site and submit such approval as described in PART 1 - SUBMITTALS.
- .3 Factory assemble control panels and component assemblies.
-

2.2 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS .1 Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.

.2 Control wiring conduit: in accordance with Section 26 05 34 except for conduit, wiring and connections below 50 V which are related to control systems specified in mechanical sections and as shown on mechanical drawings.

2.3 WARNING SIGNS .1 Warning Signs: in accordance with requirements of authority having jurisdiction

.2 Decal signs, minimum size 175 x 250 mm.

2.4 WIRING TERMINATIONS .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

2.5 EQUIPMENT IDENTIFICATION .1 Identify electrical equipment with nameplates as follows:

- .1 Nameplates: lamicoid 3 mm, matt white finish face, black core, lettering accurately aligned and engraved into core mechanically attached with self tapping screws.
- .2 Sizes as follows:

NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

2.7 CONDUIT AND CABLE IDENTIFICATION (Cont'd) .3 Colours:(Cont'd)

	Prime	Auxiliary
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 kV	Yellow	Blue
up to 15 kV	Yellow	Red
Telephone	Green	
Other Communication Systems	Green	Blue
Fire Alarm	Red	
Emergency Voice	Red	Blue
Other Security Systems	Red	Yellow

- 2.8 FINISHES .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
- .1 Paint outdoor electrical equipment "equipment green" finish to.
 - .2 Paint indoor switchgear and distribution enclosures light gray to EEMAC 2Y-1.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.
- .2 Do overhead and underground systems in accordance with CSA C22.3 No.1 except where specified otherwise.

- 3.2 NAMEPLATES AND LABELS .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

- 3.3 CONDUIT AND CABLE INSTALLATION .1 Install conduit and sleeves prior to pouring of concrete.
.1 Sleeves through concrete: schedule 40 steel pipe, sized for free passage of conduit, and protruding 50 mm.
.2 Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.
- 3.4 LOCATION OF OUTLETS .1 Locate outlets in accordance with Section 26 05 32 - Outlet Boxes, Conduit Boxes and Fittings.
.2 Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
.3 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation.
- 3.5 CO-ORDINATION OF PROTECTIVE DEVICES .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.
- 3.6 FIELD QUALITY CONTROL .1 Load Balance:
.1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
.2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
.3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
-

- 3.6 FIELD QUALITY CONTROL
(Cont'd)
- .2 Conduct following tests in accordance with Section 01 45 00 - Testing and Quality Control.
- .1 Power distribution system including phasing, voltage, grounding and load balancing.
 - .2 Circuits originating from branch distribution panels.
 - .3 Lighting and its control.
 - .4 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
 - .5 Insulation resistance testing:
 - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
 - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
 - .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative, Engineer.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.
- .5 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.
- 3.7 CLEANING
- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
 - .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

Cell Upgrades	WIRES AND CABLES	Section 26 05 21
Shepody Healing Center	(0-1000 V)	
Dorchester Penitentiary		
Project No R.043937.001		Dec 2012

- 1.1 PRODUCT DATA .1 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.
- 1.2 DELIVERY, STORAGE AND HANDLING .1 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates paddling and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

- 2.1 BUILDING WIRES .1 Conductors: stranded for 10 AWG and larger. Minimum size: 12 AWG.
- .2 Copper conductors: size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE, Non Jacketted.

PART 3 - EXECUTION

- 3.1 FIELD QUALITY CONTROL .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform tests using method appropriate to site conditions and to approval of Departmental Representative and Engineer and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- 3.2 GENERAL CABLE INSTALLATION .1 Conductor length for parallel feeders to be identical.
- .2 Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.
- .3 Wiring in walls: typically drop or loop vertically from above to better facilitate
-

- 3.2 GENERAL CABLE INSTALLATION (Cont'd) .3 Wiring in walls:(Cont'd)
future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.
- .4 Provide numbered wire collars for control wiring. Numbers to correspond to control shop drawing legend. Obtain wiring diagram for control wiring.
- 3.3 INSTALLATION OF BUILDING WIRES .1 Install wiring as follows:
- .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

PART 1 - GENERAL

- 1.1 RELATED SECTIONS
- .1 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
 - .2 Section 26 05 00 - Common Work Results - Electrical.
- 1.2 REFERENCES
- .1 American National Standards Institute (ANSI)/Institute of Electrical and Electronics Engineers (IEEE)
 - .1 ANSI/IEEE 837-1989(R1996), Qualifying Permanent Connections Used in Substation Grounding.
 - .2 Canadian Standards Association, (CSA International)
- 1.3 WASTE MANAGEMENT AND DISPOSAL
- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
 - .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
 - .3 Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
 - .4 Divert unused metal materials from landfill to metal recycling facility as approved by Engineer Consultant.
 - .5 Fold up metal banding, flatten and place in designated area for recycling.
-

PART 2 - PRODUCTS

- 2.1 EQUIPMENT
- .1 Insulated grounding conductors: green, type RW90.
 - .2 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
 - .1 Grounding and bonding bushings.
 - .2 Protective type clamps.
 - .3 Bolted type conductor connectors.
 - .4 Bonding jumpers, straps.
 - .5 Pressure wire connectors.

PART 3 - EXECUTION

- 3.1 INSTALLATION GENERAL
- .1 Install complete permanent, continuous grounding system including, conductors, connectors, accessories. Where EMT is used, run ground wire in conduit.
 - .2 Install connectors in accordance with manufacturer's instructions.
 - .3 Protect exposed grounding conductors from mechanical injury.
 - .4 Use mechanical connectors for grounding connections to equipment provided with lugs.
 - .5 Soldered joints not permitted.
 - .6 Install bonding wire for flexible conduit, connected at one end to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
 - .7 Install flexible ground straps for bus duct enclosure joints, where such bonding is not inherently provided with equipment.
 - .8 Make grounding connections in radial configuration only, with connections terminating at single grounding point . Avoid loop connections.
-

PART 1 - GENERAL

- | | | |
|--|----|---|
| <u>1.1 RELATED
SECTIONS</u> | .1 | Section 01 74 21 - Construction/Demolition
Waste Management And Disposal. |
| <u>1.2 WASTE
MANAGEMENT AND
DISPOSAL</u> | .1 | Separate and recycle waste materials in
accordance with Section 01 74 21 -
Construction/Demolition Waste Management And
Disposal. |
| | .2 | Remove from site and dispose of all packaging
materials at appropriate recycling facilities. |
| | .3 | Collect and separate for disposal paper
plastic polystyrene corrugated cardboard
packaging material in appropriate on-site bins
for recycling in accordance with Waste
Management Plan. |
| | .4 | Divert unused metal materials from landfill
to metal recycling facility as approved by
Engineer Consultant. |
| | .5 | Fold up metal banding, flatten and place in
designated area for recycling. |

PART 2 - PRODUCTS

CHANNELS

PART 3 - EXECUTION

- | | | |
|-------------------------|----|---|
| <u>3.1 INSTALLATION</u> | .1 | Secure equipment to masonry, tile and plaster
surfaces with lead anchors or nylon shields. |
| | .2 | Secure equipment to poured concrete with
expandable inserts. |
| | .3 | Secure equipment to hollow masonry walls or
suspended ceilings with toggle bolts. |
| | .4 | Secure surface mounted equipment with twist
clip fasteners to inverted T bar ceilings. |
-

- 3.1 INSTALLATION (Cont'd)
- .4 (Cont'd)
Ensure that T bars are adequately supported to carry weight of equipment specified before installation.
 - .5 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
 - .6 Fasten exposed conduit or cables to building construction or support system using straps.
 - .1 One-hole steel straps to secure surface conduits and cables 50 mm and smaller.
 - .2 Two-hole steel straps for conduits and cables larger than 50 mm.
 - .3 Beam clamps to secure conduit to exposed steel work.
 - .7 Suspended support systems.
 - .1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.
 - .2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod hangers where direct fastening to building construction is impractical.
 - .8 For surface mounting of two or more conduits use channels.
 - .9 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
 - .10 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
 - .11 Do not use nylon straps, wire lashing or perforated strap to support or secure raceways or cables.
 - .12 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of Engineer.
 - .13 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canadian Standards Association (CSA International)
.1 CSA C22.1, Canadian Electrical Code, Part 1.
- 1.2 SUBMITTALS .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- 1.3 DELIVERY, STORAGE AND HANDLING .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
.2 Waste Management and Disposal:
.1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

- 2.1 OUTLET AND CONDUIT BOXES GENERAL .1 Size boxes in accordance with CSA C22.1.
.2 102 mm square or larger outlet boxes as required.
.3 Gang boxes where wiring devices are grouped.
.4 Blank cover plates for boxes without wiring devices.
- 2.2 CONCRETE BOXES .1 Electro-galvanized sheet steel concrete type boxes for flush mount in concrete with matching extension and plaster rings as required.
-

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canadian Standards Association (CSA International)
.1 CAN/CSA C22.2 No. 18-98(R2003), Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware, A National Standard of Canada.
.2 CSA C22.2 No. 45-M1981(R2003), Rigid Metal Conduit.
.3 CSA C22.2 No. 56-04, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
.4 CSA C22.2 No. 83-M1985(R2003), Electrical Metallic Tubing.
.5 CSA C22.2 No. 211.2-M1984(R2003), Rigid PVC (Unplasticized) Conduit.
.6 CAN/CSA C22.2 No. 227.3-05, Nonmetallic Mechanical Protection Tubing (NMPT), A National Standard of Canada (February 2006).
- 1.2 SUBMITTALS .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
.2 Product data: submit manufacturer's printed product literature, specifications and datasheets.
.1 Submit cable manufacturing data.
.3 Quality assurance submittals:
.1 Test reports: submit certified test reports.
.2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
.3 Instructions: submit manufacturer's installation instructions.
- 1.3 WASTE MANAGEMENT AND DISPOSAL .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
.2 Place materials defined as hazardous or toxic waste in designated containers.
-

1.3 WASTE .3 Ensure emptied containers are sealed and
MANAGEMENT AND stored safely for disposal away from children.
DISPOSAL
(Cont'd)

PART 2 - PRODUCTS

2.1 CABLES AND .1 Provide cables on reels or coils.
REELS

.1 Mark or tag each cable and outside of
each reel or coil, to indicate cable length,
voltage rating, conductor size, and
manufacturer's lot number and reel number.

.2 Each coil or reel of cable to contain only
one continuous cable without splices.

.3 Identify cables for exclusively dc
applications.

.4 Reel and mark shielded cables rated 2,001
volts and above.

2.2 CONDUITS .1 Electrical metallic tubing (EMT): to CSA
C22.2 No. 83, with couplings.

2.3 CONDUIT .1 One hole steel straps to secure surface
FASTENINGS conduits 50 mm and smaller.
.1 Two hole steel straps for conduits
larger than 50 mm.

.2 Beam clamps to secure conduits to exposed
steel work.

.3 Channel type supports for two or more
conduits.

.4 Threaded rods, 6 mm diameter, to support
suspended channels.

2.4 CONDUIT .1 Fittings: to CAN/CSA C22.2 No. 18,
FITTINGS manufactured for use with conduit specified.
Coating: same as conduit.

2.4 CONDUIT .2 Ensure factory "ells" where 90 degrees bends
FITTINGS for 25 mm and larger conduits.
(Cont'd) .3 Set-screw steel connectors and couplings for
EMT.

2.5 FISH CORD .1 Polypropylene.

PART 3 - EXECUTION

3.1 MANUFACTURER'S .1 Compliance: comply with manufacturer's
INSTRUCTIONS written recommendations or specifications,
including product technical bulletins,
handling, storage and installation
instructions, and datasheets.

3.2 INSTALLATION .1 Install conduits to conserve headroom in
exposed locations and cause minimum
interference in spaces through which they
pass.
.2 Conceal conduits except in mechanical and
electrical service rooms in unfinished areas.
.3 Use rigid galvanized steel threaded conduit
except where specified otherwise.
.4 Minimum conduit size for lighting and power
circuits: 19 mm.
.5 Field threads on rigid conduit must be of
sufficient length to draw conduits up tight.
.6 Install fish cord in empty conduits.
.7 Dry conduits out before installing wire.
.8 Use rigid conduit where exposed, except in
Mechanical and Electrical room, or where run
at ceiling.

- 3.3 SURFACE CONDUITS
- .1 Run parallel or perpendicular to building lines.
 - .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
 - .3 Run conduits in flanged portion of structural steel.
 - .4 Group conduits wherever possible on channels.
 - .5 Do not pass conduits through structural members except as indicated.
 - .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.
- 3.4 CONCEALED CONDUITS
- .1 Run parallel or perpendicular to building lines.
 - .2 Do not install horizontal runs in masonry walls.
 - .3 Do not install conduits in terrazzo or concrete toppings.
- 3.5 CLEANING
- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
 - .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

- | | | |
|---|----|--|
| <u>1.1 SECTION INCLUDES</u> | .1 | Switches, receptacles, wiring devices, cover plates and their installation. |
| <u>1.2 RELATED SECTIONS</u> | .1 | Section 01 33 00 - Submittal Procedures. |
| | .2 | Section 01 74 19 - Construction/Demolition Waste Management And Disposal. |
| | .3 | Section 26 05 01 - Common Work Results - Electrical. |
| <u>1.3 REFERENCES</u> | .1 | Canadian Standards Association (CSA International)
.1 CSA-C22.2 No.42-99(R2002), General Use Receptacles, Attachment Plugs and Similar Devices.
.2 CSA-C22.2 No.42.1-00, Cover Plates for Flush-Mounted Wiring Devices (Bi-national standard, with UL 514D).
.3 CSA-C22.2 No.55-M1986(July 2001), Special Use Switches.
.4 CSA-C22.2 No.111-00, General-Use Snap Switches (Bi-national standard, with UL 20, twelfth edition). |
| <u>1.4 SHOP DRAWINGS AND PRODUCT DATA</u> | .1 | Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures. |
| <u>1.5 WASTE MANAGEMENT AND DISPOSAL</u> | .1 | Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal. |
| | .2 | Remove from site and dispose of all packaging materials at appropriate recycling facilities. |
| | .3 | Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins |
-

1.5 WASTE
MANAGEMENT AND
DISPOSAL
(Cont'd)

- .3 (Cont'd)
for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Engineer Consultant.

PART 2 - PRODUCTS

2.1 SWITCHES

- .1 15 A, 120 V, specification grade, single pole, three-way, four-way switches.
- .2 Manually-operated ac switches with following features:
 - .1 Terminal holes approved for No. 10 AWG wire.
 - .2 Silver alloy contacts.
 - .3 Urea or melamine molding for parts subject to carbon tracking.
 - .4 Suitable for back and side wiring.
 - .5 White toggle.
- .3 Toggle operated fully rated for tungsten filament and fluorescent lamps, and up to 80% of rated capacity of motor loads.
- .4 Switches of one manufacturer throughout project.
- .5 Acceptable materials:
 - .1 Hubbell: 1201 to 1204
 - .2 Leviton: 1201 to 1204
 - .3 Bryant: 4801 to 4804
 - .4 Pass & Seymore: 15AC1 to 15AC4

2.2 RECEPTACLES

- .1 Duplex receptacles, CSA type 5-15 R, 125 V, 15 A, U ground, with following features:
 - .1 White urea molded housing.
 - .2 Suitable for No. 10 AWG for back and side wiring.
 - .3 Break-off links for use as split receptacles.
 - .4 Eight back wired entrances, four side wiring screws.

2.2 RECEPTACLES
(Cont'd)

- .1 (Cont'd)
 - .5 Triple wipe contacts and rivetted grounding contacts.
- .2 Receptacles of one manufacturer throughout project.
- .3 Acceptable materials:
 - .1 Hubbell: 5262
 - .2 Leviton: 5262
 - .3 Bryant: 5262
 - .4 Pass & Seymore: 5262
- .4 Other receptacles with ampacity and voltage as indicated.

2.3 COVER PLATES

- .1 Cover plates for wiring devices to: CSA-C22.2 No.42.1.
 - .2 Cover plates from one manufacturer throughout project.
 - .3 Sheet steel utility box cover for wiring devices installed in surface-mounted utility boxes.
 - .4 Stainless steel, vertically brushed, 1 mm thick cover plates for wiring devices mounted in flush-mounted outlet box.
 - .5 Cast cover plates for wiring devices mounted in surface-mounted FS or FD type conduit boxes.
 - .6 Weatherproof double lift spring-loaded cast aluminum cover plates, complete with gaskets for duplex receptacles as indicated.
-

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Switches:
 - .1 Install single throw switches with handle in "UP" position when switch closed.
 - .2 Install switches in gang type outlet box when more than one switch is required in one location.
 - .3 Mount toggle switches at height in accordance with Section 26 05 01 - Common Work Results - Electrical as indicated.
- .2 Receptacles:
 - .1 Install receptacles, with U ground UP, in gang type outlet box when more than one receptacle is required in one location.
 - .2 Mount receptacles at height in accordance with Section 26 05 01 - Common Work Results - Electrical as indicated.
 - .3 Where split receptacle has one portion switched, mount vertically and switch upper portion.
- .3 Cover plates:
 - .1 Protect stainless steel cover plate finish with paper or plastic film until painting and other work is finished.
 - .2 Install suitable common cover plates where wiring devices are grouped.
 - .3 Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.