

**Part 1            General****1.1                RELATED SECTIONS**

- .1     Section 01 00 10 – General Instructions.
- .2     Section 26 05 00 - Common Work Results for Electrical.
- .3     Section 26 23 00 – Low Voltage Switchgear.

**1.2                REFERENCES**

- .1     Canadian Standards Association, (CSA International)
  - .1     CAN3-C17-M84 (R2004), Alternating - Current Electricity Metering.
  - .2     CAN/CSA C22.2 No. 61010-1-2004 – Safety Requirements for Electrical Equipment for measurement control and Laboratory Use – Part 1: General Requirements. (Adopted IEC 1010-1:1990 with modifications), Includes Update No. 1 (2008).
- .2     Institute of Electrical and Electronics Engineers (IEEE)
  - .1     IEEE C37.90.1-2002, Surge Withstand Capabilities (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus.

**1.3                PRODUCT DATA**

- .1     Submit product data in accordance with Section 01 00 10 – General Instructions.
- .2     Indicate meter, outline dimensions, and mounting arrangement.

**1.4                WASTE MANAGEMENT AND DISPOSAL**

- .1     Separate and recycle waste materials in accordance with Section 01 00 10 – General Instructions.
- .2     Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3     Collect and separate for disposal all packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4     Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Departmental Representative.
- .5     Fold up metal banding, flatten and place in designated area for recycling.

**Part 2 Products****2.1 CURRENT TRANSFORMERS L.V.**

- .1 Provide current transformers in accordance with the following:
  - .1 Current transformers for customer metering; one per phase and one on neutral. Window type mounted and connected on load side bus of main breaker.
  - .2 Vacuum impregnated core and coils, epoxy moulded, totally encapsulated construction.
  - .3 Rating Data:
    - .1 Voltage Class - 600 V.
    - .2 Primary Current as indicated.
    - .3 60 Hz metering accuracy - 0.3 to 0.9 - for revenue class metering.
    - .4 Thermal continuous rating - 150%.
    - .5 1 minute primary - high pressure - 4.0 kV.
    - .6 1 minute secondary - 2.5 kV.
    - .7 Impulse - 10 kV full wave.
    - .8 One per phase and one for neutral.

**2.2 POTENTIAL TRANSFORMERS – L.V.**

- .1 Open type, protected by HRC current limiting fuses.
- .2 Three (3) per set, connected line to ground.
- .3 Rating Data:
  - .1 Voltage Rating: 360 V primary, 120 V secondary - 60 Hz.
  - .2 Metering Accuracy: 0.5% or better.
  - .3 Primary insulation test: 4.0 kV.
  - .4 55° C rise.
  - .5 Capable of withstanding 25% higher than nominal voltages.
  - .6 Thermal rating: 100 VA.

**2.3 DIGITAL METER**

- .1 The Digital AC Instrumentation Package shall be capable of measuring, calculating and directly displaying on the front panel display the following information in user programmable groups:
  - .1 Voltage line-to-neutral and line-to-line for each phase and average of all three phases.
  - .2 % voltage unbalance.
  - .3 Current for each phase and average of all three phases.
  - .4 % current unbalance.

- 
- .5 Neutral or ground current.
  - .6 kW for each phase and total of all three phases.
  - .7 kVAR for each phase and total of all three phases.
  - .8 kVA for each phase and total of all three phases.
  - .9 kWh for total of all three phases, provided as accumulating import, export, net and total readings.
  - .10 kVARh for total of all three phases, provided as accumulating import, export, net and total readings.
  - .11 kVAh for total of all three phases, provided as an accumulating net reading.
  - .12 Power factor for each phase and total of all three phases.
  - .13 Frequency.
  - .14 Voltage for the auxiliary voltage input.
  - .15 Harmonic distortion for each voltage and current input, provided as individual harmonic magnitudes up to the 15th harmonic, and as total odd, total even and total overall harmonic distortion.
  - .16 K-Factor calculations of the first 15 harmonics for all voltage and current inputs.
  - .17 Thermal demands for all real-time parameters, including harmonic distortion, with user-programmable length of demand period to match local utility billing method.
  - .18 Sliding window demands for up to 10 user-programmable parameters with user-programmable length of demand period and number of sub-periods to match local utility billing method.
  - .19 Predicated demand calculations for sliding window demand parameters. User programmable predictive response characteristics.
  - .20 Minimums and maximums for all real-time, thermal demand, sliding window demand, predictive sliding window demand and harmonic distortion parameters.
- .2 The instrumentation package shall include:
- .1 True RMS measurement
  - .2 Connect directly to PTs and CTs. Provide current input overrange options from 125% to 1000%.
  - .3 Supplied with a fourth current input for measurement of neutral current.
  - .4 Four optically isolated, self-excited, dry contact digital (status) inputs, maximum 277 VAC/VDC.
  - .5 One auxiliary analog input rated 1.0 VAC/VDC nominal full scale input which can be used to measure an external variable.
  - .6 One auxiliary analog output (selectable 0-20 mA or 4-20 mA) proportional to any measured parameter.
  - .7 Three Form C dry contact electromechanical control relay outputs rated 277 VAC or 30 VDC @ 10 Amp maximum load current.

- .8 Store in non-volatile memory the following:
- .1 A time-stamped alarm and event log of up to 100 events which records event date, time, event type, and value for all over/under limit conditions, digital (status) input activity, relay operations, and self-diagnostics operations. Time stamps for each event shall be provided with a resolution of 1 millisecond.
  - .2 All setup data.
- .9 System with waveform capture and recording capability allowing any of the eight (8) voltage and current input channels.
- .10 Display with 3-field, 20 character, high visibility 10 mm character height vacuum-fluorescent display with a programmable time-out feature.
- .11 Communications port with:
- .1 RJ45 port for integration to EMCS via an Ethernet TCP/IP network.
  - .2 Communication in accordance with the ASHRAE Bacnet IP protocol.
- .12 Field programmable as follows:
- .1 Voltage input scale, voltage mode (wye, delta, single phase), current input scale, auxiliary input and output scales, and communications setup parameters are programmable from the front panel.
  - .2 All parameters in (.1) above, plus additional set point/relay and data log setup parameters may be programmed via the communications port using a portable or remotely located computer terminal.
  - .3 The programming shall be password protected.
- .13 Meet the following standards:
- .1 UL listed.
  - .2 CSA approved.
  - .3 Voltage, current, status, relay and power inputs pass the IEEE C.37.90.1, Surge Withstand Capabilities (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus.
  - .4 Certified to comply with FCC Part 15 Subpart J for Class A computing devices.
- .14 Have surge protection of 300 Amps for one second on all four current inputs.
- .15 Have the following accuracy, resolution, range, and power supply ratings specifications:

<b>PARAMETER</b>	<b>ACCURACY</b> (% full scale)
Phase Voltage	0.2%
Phase Current	0.2%
kW	0.4%
kVAR	0.4%
kVA	0.4%
kWh	0.4%
kVARh	0.4%

**2.4 TEST TERMINAL BLOCKS**

- .1 Test terminal blocks: as required.

**Part 3 Execution**

**3.1 METERING INSTALLATION**

- .1 Install meters current and potential transformers in switchgear as per drawings.
- .2 Make connections in accordance with manufacturer's diagrams.

**3.2 FIELD QUALITY CONTROL**

- .1 Conduct tests in accordance with Section 01 00 10 – General Instructions and in accordance with manufacturer's recommendations.
- .2 Perform simulated operation tests with metering, instruments disconnected from permanent signal and other electrical sources.
- .3 Verify correctness of connections, polarities of meters, instruments, potential and current transformers, transducers, signal sources and electrical supplies.
- .4 Perform tests to obtain correct calibration.
- .5 Complete full setup and connection of meter communication to client network and configuration of IP address.
- .6 Do not dismantle meters and instruments.

**END OF SECTION**