

Part 1 General**1.1 RELATED SECTIONS**

- .1 Section 01 00 10 – General Instructions.
- .2 Section 21 05 01 - Common Work Results for Mechanical.

1.2 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .2 National Fire Protection Association (NFPA)
 - .1 NFPA (Fire) 10, Portable Fire Extinguishers 2007 Edition.

1.3 SUBMITTALS

- .1 Provide submittals in accordance with Section 01 00 10 – General Instructions.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Provide shop drawings.
- .4 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 00 10 – General Instructions.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle materials in accordance with Section 01 00 10 – General Instructions.
- .2 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 00 10 – General Instructions.

Part 2 Products**2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS**

- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection complete with wall mounting bracket.
 - .1 Size: 2.25 kg.

2.2 IDENTIFICATION

- .1 Identify extinguishers in accordance with recommendations of NFPA (Fire) 10.
- .2 Attach bilingual label to extinguishers, indicating month and year of installation. Provide space for service dates.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install or mount extinguishers on walls in accordance with NFPA (Fire) 10.
- .2 Supply brackets and all required accessories to install the extinguishers.

3.3 FIELD QUALITY CONTROL

- .1 Manufacturer's Field Services:
 - .1 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

END OF SECTION