



Mechanical design group

100 - 2330 15th Avenue, Regina, SK Canada S4P 1A2

phone : (306) 777-0123

fax : (306) 525-6780

June 7, 2013

File: 12-025.1

Attn: Ian Kydd
Works Unit
P.O. 6500
Regina, Sask.
S4P 3J7
Fax: (306) 780-7779

RE : Government of Canada, Innisfail, Alberta - Dog Training Facility New Fire Protection System Addendum

The following amendments to the tender documents shall be incorporated in, and form part of, the tender documents the same as if these had been written into the original tender documents.

1. General,

- .1 All piping to be buried a minimum of 2700mm over finished grade from top of pipe unless noted to be buried deeper.

2. Reference mechanical drawing M2,

- .1 Delete reference to mechanical specifications for WC-1 and associated tank description. There is no WC-1 tank required.

3. Reference structural drawing S1.1,

- .1 Bottom well slab is to be by this contractor. Provide a minimum 6" thick concrete slab. Standard reinforcing for slab on grade construction required. Seal bottom of pit at slab and well wall.