


GSC-A2 DATE PLOTTED: 2012/03/08 PLOT SCALE: 1:1 CAD FILE: S:\PRS\CAD\GROUP\CITY\ADDRESS\PROJECT\_NO\FILE.DWG

CONTRACTOR TO PROVIDE FOR HOARDING TO EXIT STAIR 241. MAINTAIN ACCESS TO EXIT COMPLETE w/ TIMES EMERGENCY LIGHTING AND EXIT SIGNS AT ALL TIMES BUILDING IS OCCUPIED. ALL WORK TO BE COORDINATED WITH DEPARTMENTAL REPRESENTATIVE

CONTRACTOR TO DETERMINE LOCATION OF ALL EXISTING DUCTWORK IN CEILING AREAS IMPACTED BY INSTALLATION OF NEW STEEL FRAMING. TEMPORARILY DISMANTLE OR REMOVE AS REQUIRED IN ORDER TO ACCESS CEILING SPACE. REINSTATE AS SOON AS POSSIBLE AS DIRECTED BY DEPARTMENTAL REPRESENTATIVE

TENDER PRICE TO ALLOW FOR REMOVAL AND REINSTALLATION OF ALL EXISTING MECHANICAL AND ELECTRICAL SERVICES TO PROVIDE CLEARANCE FOR STRUCTURAL REINFORCEMENT SCOPE OF WORK



REFERENCE PLAN

drawing title  
titre du projet  
PARTIAL SECOND FLOOR REFLECTED CEILING PLAN

project title  
titre du projet  
Rooftop Chiller Enclosure  
Government of Canada Building  
11 Station Street  
Belleville, Ontario



Do not scale drawings. Verify all dimensions and conditions on site and immediately notify the Departmental Representative of all discrepancies.

04		
03	ISSUED FOR BID	2013.05.17
02	ISSUED FOR BID	2013.04.12
01	FOR REVIEW	2013.03.01
revision		date

**DIALOG**<sup>TM</sup>

Public Works and Government Services Canada  
Travaux publics et Services gouvernementaux Canada

drawn by dessiné par	SA
designed by conçue par	RN
approved by approuvé par	JA
bid offre	IA
project date date du projet	2012-06-08
project no. no. du projet	DIALOG NO. 09769T0100 R.049400.003
drawing no. dessiné no.	A2.04