

Project No.: 719147

June 17, 2013

The following changes to the tender documents are effective immediately and will form part of the contract documents:

ATT4 - CLARIFICATION: Question and Answer

Clarification:

Question: The majority of the drawings indicate that the wharf is to remain operational, including electrical, during the renovation, but the electrical drawing basically says to disconnect and remove panels and transformers etc. for the work period and re-install when complete.

Answer: The electrical is to be disconnected during construction. As for the wharf remaining operational during construction, the Centre Wharf will be closed to the public during construction; however, the contractor is to install owner (SCH) supplied floating docks to provide access for boaters to the existing floating docks on the south side of the wharf per Drawing G-1.