

## Mechanical Addendum M-03

Project Name: RCMP Heating and Controls Upgrade	
Client: RCMP "K" Division	
Project No.: 26877.00	Date: June 19, 2013
Distribution: Ron SETO NWT Project Management Office ron.seto@rcmp-grc.gc.ca	

This addendum forms part of the Contract Documents and is to be read, interpreted, and coordinated with all other parts. The cost of all work contained herein is to be included in the Contract Sum. The specifications and drawings are complementary. Items listed under the specification in this addendum and having influence on the drawings are so deemed to alter the drawings. Items listed under the drawings in this addendum and having influence on the specification are so deemed to alter the specification

---

**1. Response to Questions**

- Q#1** Requirements for boiler B-1 and B-2 are listed on equipment list as Weil McLain 80 series with an output of 70.86kW (242 MBH) and input of 2.4GPH oil. Would Weil McLain Gold Oil 7's with a Riello boiler be accepted as a substitute?
- A#1** Weil McLain Gold Oil WGO-7 has a DOE heating capacity of of 242 MBH and a Net IBR capacity of 210 MBH, and a burner capacity of 2.0GPH. This will be accepted as a substitution. If this boiler is used, the contractor is to ensure breaching and chimney sizes are modified if required to meet manufacturer's installation requirements and applicable codes if a substitution is made.

Prepared by,

Williams Engineering Canada Inc.

**Elaine Carr, P.Eng.**  
Mechanical Team Lead

T 867.873.2395 F 867.873.2547  
Ecarr@williamsengineering.com

End of Addendum No. M-03