



1. DISCONNECT POWER & CONTROL CABLE FOR EXISTING FLOW METER ELEMENT IN CHAMBER AND LCD DISPLAY INSIDE BLDG. RECONNECT SAME TO NEW METER ELEMENT AND LCD DISPLAY. REFER TO E-002 AND P-002 FOR METER LOCATION.
2. PROTECTION TO BE DETERMINED BY MANUFACTURER.
3. TVSS IS THREE PHASE (3ø) LINE-GROUND MOV TYPE, DIGITAL TRANSIENT COUNTER AND FAILED MOV INDICATING LIGHTS AND FORM "C" ALARM CONTACT. CLAMPING VOLTAGE UNDER ANSI/IEEE C62.41 CATEGORY C3. ACCEPTABLE SUPPLIER: CUTLER-HAMMER CPS-S OR EQUAL. BREAKER TO BE SIZED BY SUPPLIER.