

Project No.: 719147

June 19, 2013

The following changes to the tender documents are effective immediately and will form part of the contract documents:

ATT7 - CLARIFICATION: Question and Answer

Clarification:

Question: In regards to tests required, are the ground resistance test (main service and grounding is already in place), and the empty conduit test really required?

Answer: Yes, all tests of Section 26 05 01 – Common Work Results Electrical, 3.8.2, are required.