



Temperature (°C)	Growth (%)
0	0
10	0
20	10
30	40
40	60
50	50
60	30
70	10
80	0
90	0
100	0

① PROVIDE A NEW CIRCUIT BREAKER TO MATCH EXISTING (EATON PANELBOARD PRL300 HKD TYPE BREAKER, 25KA).  
COORDINATE OUTAGE WITH INSTITUTION; WORK TO BE DONE OUTSIDE OF NORMAL WORKING HOURS.

