

PART 1 - GENERAL

- | | | |
|------------------------------|----|---|
| <u>1.1 RELATED SECTIONS</u> | .1 | Section 01 33 00 - Submittal Procedures. |
| | .2 | Section 01 35 29.06 - Health and Safety Requirements. |
| | .3 | Section 26 05 00 - Common Work Results - Electrical. |
| <u>1.2 REFERENCES</u> | .1 | Canadian Standards Association (CSA International). |
| | .1 | CAN/CSA C22.2 No.4-M89 (R2000), Enclosed Switches. |
| | .2 | CSA C22.2 No.39-M89 (R2003), Fuseholder Assemblies. |
| <u>1.3 SUBMITTALS</u> | .1 | Submit product data in accordance with Section 01 33 00 - Submittal Procedures. |
| <u>1.4 HEALTH AND SAFETY</u> | .1 | Do construction occupational health and safety. |

PART 2 - PRODUCTS

- | | | |
|--------------------------------|----|---|
| <u>2.1 DISCONNECT SWITCHES</u> | .1 | Non-fusible, horsepower rated disconnect switch in CSA Enclosure as indicated, to CAN/CSA C22.2 No.4 size as indicated. |
| | .2 | Provision for padlocking in on-off switch position by three locks. |
| | .3 | Mechanically interlocked door to prevent opening when handle in ON position. |
| | .4 | Quick-make, quick-break action. |
| | .5 | ON-OFF switch position indication on switch enclosure cover. |
-

- 2.2 EQUIPMENT IDENTIFICATION
- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
 - .2 Indicate name of load controlled on size 4 nameplate.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Install disconnect switches complete with fuses if applicable.